

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

DR806 | 1120

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-806 **Effective Date:** November 1, 2020

Re-evaluation Date: November 2024

Product Name: 8'-0" Craftsmen Series Glazed Fiberglass Side Hinged Doors, Inswing and

Outswing, Singles, with or without Sidelites, Non-Impact Resistant

Manufacturer: Plastpro, Inc.

5200 West Century Boulevard

Los Angeles, CA 90045

(440) 969-9773

General Description:

System	Description	Label Rating	Drawing Number
1	3'-0" x 8'-0" Single Door; X	Inswing: +35 / -50 psf Outswing: +40 / -40 psf	TX-4611
2	3'-0" x 8'-0" Single Door w/ Sidelite & Combination Integral Mullion; OX, XO	Inswing: +35 / -50 psf Outswing: +40 / -40 psf	TX-4611
3	3'-0" x 8'-0" Single Door w/ Sidelites & Combination Integral Mullions; OXO	Inswing: +35 / -50 psf Outswing: +40 / -40 psf	TX-4611

Product Dimensions:

System	Maximum Overall Size	Operable Panel Size	Maximum Panel Daylight Opening Size
1	37-1/2" x 98"	35-3/4" x 95-7/16"	Door: 24-3/4" x 22" Sidelite: 7-1/2" x 21-3/4"

Product Dimensions:

System	Maximum Overall Size	Operable Panel Size	Maximum Panel Daylight Opening Size
2	53" x 98"	35-3/4" x 95-7/16"	Door: 24-3/4" x 22" Sidelite: 7-1/2" x 21-3/4"
3	68-1/2" x 98"	35-3/4" x 95-7/16"	Door: 24-3/4" x 22" Sidelite: 7-1/2" x 21-3/4"

Components and Hardware:

System	Component	Quantity	Attachment Method
	Hinges	4	
1-3	Knob: Kwikset 400 Series Deadbolt: Kwikset 660 Series OR Knob: Schlage F-Series Deadbolt: Schlage B-Series OR Knob: Yale 100 C Deadbolt: Yale 820	1 each	Install hardware in accordance with Plastpro drawing No. TX-4611, dated April 26, 2016. Revision 1 dated May 21, 2020. Signed and sealed by Lyndon F. Schmidt, P.E. on May 26, 2020.
	Latch and Deadbolt strike plate	1 each	

Product Identification (Manufacturer Label on Door):

· · · · · · · · · · · · · · · · · · ·	The carrow (managed are label on boot).		
System			
	Manufacturer's name	Plastpro, Inc.	
	Product name	Craftsmen Series Glazed Fiberglass Side Hinged Doors,	
1-3		Inswing & Outswing, Non-Impact Resistant Door	
		Panels, Singles w/ or w/out Sidelites	
	Test standards	ASTM E330-14	

Impact Resistance:

System	Impact Resistant	Requirement
1-3	No	Provide an impact protective system when installing the product in areas that require windborne debris.

Acceptance of Smaller Assemblies: Door assemblies with dimensions smaller than those specified are acceptable within the limitations of this report.

Installation:

System		
	Type of installation Wall framing	Install in accordance with Plastpro drawing No.
1-3	Fasteners	TX-4611, dated April 26, 2016. Revision 1 dated May 21, 2020. Signed and sealed by Lyndon F. Schmidt, P.E. on
	Fastener location/spacing	May 26, 2020.
	Fastener penetration	, = 3/ = 3 = 3

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.