

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

## **Product Evaluation**

DR870 | 0122

**Engineering Services Program** 

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

**Evaluation ID:** DR-870 **Effective Date:** January 1, 2022

**Re-evaluation Date:** January 2026

Product Name: Ultimate Aluminum Clad Wood Glazed Sliding French Doors, Frame Installation,

Non-Impact Resistant

**Manufacturer:** Marvin

P.O. Box 100 Highway 11 West Warroad, MN 56763 (218) 386-4021

### **General Description:**

System	Description	Label Rating	Design Pressure Rating
1	Ultimate Clad Wood Sliding French Doors, Low Profile Sill; XO	LC-PG35 (72.63 x 107.5)	+35 / -35 psf
2	Ultimate Clad Wood Sliding French Doors; XO	LC-PG40 (72.63 x 107.5)	+40 / -40 psf

### **Product Dimensions:**

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1-2	72-5/8" x 107-1/2"	37-1/4" x 104-1/2"	27-3/4" x 95"

# **Product Identification (Certification Label on Door):**

System			
	Certification agency	WDMA	
1	Manufacturer's name or code name	Marvin	
'	Product name	UL SLD FRDR LPS	
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-08,11	
	Certification agency	WDMA	
2	Manufacturer's name or code name	Marvin	
2	Product name	UL SLD FRDR	
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-08,11	

## **Impact Resistance:**

System	Impact Resistant	Requirement
1-2	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

## Installation:

System			
	Type of installation	Frame Installation	
	Wall framing	Spruce-Pine-Fir dimension lumber	
1-2	Fasteners	No. 8 x 3" screws	
1-2	Fastener location/spacing	6" from each corner and 12" on center	
		along the head and side jambs	
	Fastener penetration	Minimum of 1-1/2" into the wall framing	
	Type of installation	Frame Installation-Structural Brackets	
		(0.050" x 1.56" x 5.151" galvanized steel)	
	Wall framing	Spruce-Pine-Fir dimension lumber	
1-2	Fasteners	Window frame: two No. 8 x 5/8" screws	
1-2		Wall Framing: two No. 8 screws	
	Fastener location/spacing	6" from each corner and 12" on center	
		along the head and side jambs	
	Fastener penetration	Minimum of 1-1/2" into the wall framing	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.