

Product Evaluation

DR875 | 0621

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-875

Effective Date: June 1, 2021

Re-evaluation Date: June 2025

Product Name: HPC Wood Edge Steel Glazed Inswing and Outswing Side Hinged Doors, with or without Sidelites, Frame Installation, Non-Impact Resistant

Manufacturer: Masonite International
1955 Powis Road
West Chicago, IL 60185
(630) 584-6330

General Description:

System	Description	Design Pressure Rating
1	6'-8" Wood Edge Steel Glazed Inswing Door w/ Sidelites; OXXO	+50 / -50 psf
2	6'-8" Wood Edge Steel Glazed Outswing Door w/ Sidelites; OXXO	+50 / -50 psf

Product Dimensions:

System	Overall Size	Operable Panel Size	Panel Daylight Opening Size
1	148-5/8" x 81-5/8"	35-3/4" x 79"	Door & Sidelite: 20-7/8" x 62-7/8"
2	148-1/2" x 80-1/2"	35-3/4" x 79"	Door & Sidelite: 20-7/8" x 62-7/8"

Components and Hardware:

- **Hinges:** four required; secured to the door panel with four No. 10 x 1" screws; secured to the door jamb with two No. 10 x 5/8" screws and two No. 10 x 2-1/2" screws.
- **Lockset:** minimum grade 3 rating as defined by ANSI/BHMA A156.2; located on the active door panel
- **Deadbolt:** grade 1 rating as defined by ANSI/BHMA A156.36; located on the active door panel
- **Strike plate – Lockset:** one required; locate on the door jamb; secured with two No. 8 x 2" screws.
- **Strike plate – Deadbolt:** one required; locate on the door jamb; secured with two No. 8 x 2" screws.
- **Astragal strike – strike plate at head:** Secure with two No. 8 x 2" screws
- **Astragal strike – sill retainer hole:** drill hole through sill deep enough for a 1-3/8" extension bolt throw.

Thresholds:

- Outswing: 0.962" high aluminum adjustable threshold (System 2)
- Outswing: 1.482" high Endura Z Series High Dam aluminum threshold (System 2)
- Outswing: 1.730" high DLP High Dam aluminum bumper threshold (System 2)
- Inswing: 1.375" high aluminum adjustable threshold (System 1)

Product Identification (Manufacturer Label on Door):

System		
1-2	Manufacturer's name	Masonite
	Product name	HPC Wood Edge Steel Glazed Door Unit with or without Sidelites Inswing or Outswing Config: X, XX, OX, XO, OXO, OXXO Max. Nominal Size: 12'0" x 8'0"
	Test standards	ASTM E330-02

NOTE: Each door is stamped "HPC" from the product manufacturer. The stamp is located on the top rail.

Compliance: The products comply with ASTM E 330-14 as reference in the 2018 IRC and 2018 IBC.

Impact Resistance:

System	Impact Resistant	Requirement
1-2	No	Provide an impact protective system when installing the product in areas that require windborne debris.

Acceptance of Smaller Assemblies: Door assemblies with dimensions equal to or smaller than those specified are acceptable within the limitations specified in this report.

Sidelites: Only use sidelites with doors. Do not install sidelites individually.

Installation:

The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The door assembly is secured to the wall framing with minimum No. 10 x 2-1/2" PFH screws. Along the head and sill, locate the screws approximately 6" from each outside corner, one at 3" and 6" on each side of the mullion and astragal, and one at the centerline of each door panel. Along the side jambs, locate the screws approximately 6" from each corner and spaced evenly thereafter, totaling six screws per jamb. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Concrete framing: If the frame is attached to concrete, substitute, minimum 3/16" diameter flat head concrete anchors. Embed the anchor a minimum of 1-1/4" into the concrete.

Note: An illustration of anchor location along the perimeter of the assembly is provided in drawing "Structural Performance Anchor Detail." Rev. 050217. An illustration of anchor placement on the frame and sill members is provided in Drawing "Anchor Placement Detail."

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.