

Product Evaluation

DR886 | 0422

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-886

Effective Date: April 1, 2022

Re-evaluation Date: January 2025

Product Name: Aluminum Clad Wood Sliding Patio Doors, Fin Installation, Non-Impact Resistant

Manufacturer: Sierra Pacific Windows
575 South Whelen Ave.
Medford, WI 54451
(715) 748-2011

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Clad Wood Sliding Patio Doors; XO	LC-PG35 (95 x 96)-SD	+35 / -35 psf

Product Dimensions:

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1	94-1/2" x 95-3/4"	47-9/16" x 93"	41-1/2" x 87-1/2"

Product Identification (Certification Label on Door):

System		
1	Certification agency	WDMA
	Manufacturer's name or code name	Sierra Pacific Windows
	Product name	Clad Sliding Patio Door
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The door assembly is secured to the wall framing with minimum 11-gauge, 2" long roofing nails with 3/8" diameter head. Locate the nails approximately 3-1/2" apart through the pre-punched holes along the perimeter. Two (2) No. 8 x 3" PFH screws and one (1) No. 10 x 3" PH screw are required at the lock keeper locating along the lock jamb. Fasteners must be long enough to penetrate a minimum of 1-1/2 PH screw at the lock keeper locating along the lock jamb into the wall framing members.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.