

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

Product Evaluation

DR931| 1023

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-931 **Effective Date:** October 1, 2023

Re-evaluation Date: October 2027

Product Name: Series 120/130/140 Aluminum Sliding Glass Doors, Frame Installation, Impact

Resistant

Manufacturer: MI Windows and Doors

650 West Market St. Gratz, PA 17030 (717) 365-3300

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 120/130/140 Aluminum Sliding Glass Doors; OXXO	LC-PG55 (191 x 120) Missile Level D	+55.0 / -55.0 psf

Product Dimensions:

System	Overall size	Operable Panel Size	Fixed Panel Daylight Opening Size
1	190-5/8" x 120"	48-5/8" x 117-1/2"	40-5/8" x 109-3/4"

Product Identification (Certification Label on Door):

System		
1	Certification agency	AAMA
	Manufacturer's name or code name	MTL-12
	Product name	Series 120
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-11
		AAMA 506
		Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System			
1	Type of installation	Frame Installation	
	Wall framing	Spruce-Pine-Fir dimension lumber	
	Fasteners	No. 14 x 2" pan head screws	
	Fastener location/spacing	Pair of screws located 6" from each corner and 16"	
		on center along the perimeter	
	Fastener penetration	Minimum of 1-1/2" into the wall framing	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.