

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

Product Evaluation

DR942 | 0521

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-942 Effective Date: May 1, 2021

Re-evaluation Date: February 2025

Product Name: Series "LPS" Glazed Fiberglass Sliding Glass Doors, Impact Resistant

Manufacturer: Nan Ya Plastics Corporation USA

8989 North Loop East, Suite 800

Houston, TX 77029 (713) 674-7822

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series "LPS" Fiberglass Sliding Glass Door w/ Sill Riser; XXO	R-PG50 (106 x 82)-SD Missile Level D	+50 / -50 psf
2	Series "LPS" Fiberglass Sliding Glass Door w/ Sill Riser & Bubble Cover; XXO	R-PG50 (106 x 82)-SD Missile Level D	+50 / -50 psf
3	Series "LPS" Fiberglass Sliding Glass Door; XXO	R-PG50 (106 x 82)-SD Missile Level D	+50 / -50 psf
4	Series "LPS" Fiberglass Sliding Glass Door; XXO	R-PG50 (106 x 95)-SD Missile Level D	+50 / -50 psf

General Description:

System	Description	Label Rating	Design Pressure Rating
5	Series "LPS" Fiberglass Sliding Glass Door w/ Sill Riser; XXO	R-PG50 (106 x 95)-SD Missile Level D	+50 / -50 psf
6	Series "LPS" Fiberglass Sliding Glass Door w/ Sill Riser & Bubble Cover; XXO	R-PG50 (106 x 95)-SD Missile Level D	+50 / -50 psf

Product Dimensions:

System	Overall size	Operable Panel Size	Fixed Panel Daylight Opening Size
1-3	106" x 82-3/16"	35-3/4" x 79-1/4"	26-1/4" x 66"
4-6	106" x 95-1/2"	35-3/4" x 92-19/32"	25" x 79"

Product Identification (Certification Label on Door):

System			
1, 5	Certification agency	NAMI	
	Manufacturer's name or code name	Nan Ya Plastics USA	
	Product name	LPS Gliding Glazed Impact Rated	
		Fiberglass Patio Door w/ Sill Riser	
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-11	
		ASTM E1886-05/E1996-05,09	
		Missile Level D	
	Certification agency	NAMI	
	Manufacturer's name or code name	Nan Ya Plastics USA	
	Product name	LPS Gliding Glazed Impact Rated	
2, 6		Fiberglass Patio Door w/ Sill Riser &	
2, 0		Bubble Cover	
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-11	
		ASTM E1886-05/E1996-05,09	
		Missile Level D	
	Certification agency	NAMI	
	Manufacturer's name or code name	Nan Ya Plastics USA	
3-4	Product name	LPS Gliding Glazed Impact Rated	
		Fiberglass Patio Door	
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-11	
		ASTM E1886-05/E1996-05,09	
		Missile Level D	

Impact Resistance:

System	Impact Resistant	Requirement
1-6	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

Type of installation Wall framing Fasteners	Install in accordance with drawing No. 08-03122, dated July 27, 2017. Revision A dated February 10 2021. Signed and sealed by Luis R. Lomas, P.E. or February 10, 2021.	
Fastener location/spacing Fastener penetration		
Type of installation Wall framing	Install in accordance with drawing No. 08-03120 dated July 27, 2017. Revision A dated February 1 2021. Signed and sealed by Luis R. Lomas, P.E. o February 10, 2021.	
Fasteners		
	Wall framing Fasteners Fastener location/spacing Fastener penetration Type of installation Wall framing	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.