	REVISIONS		
REV	DESCRIPTION	DATE	APPROVED
А	REVISED TO ADD 3/4 LITE PANEL	02/10/2021	R.L.
В	REVISED TO ADD INSTALLATION DETAILS	03/14/2022	R.L.

- 1. THE PRODUCT SHOWN HEREIN IS DESIGNED AND MANUFACTURED TO COMPLY WITH REQUIREMENTS OF THE 2018 IBC AND THE 2018 IRC.
- 2. WOOD FRAMING AND MASONRY OPENING TO BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO STRUCTURE. FRAMING AND MASONRY OPENING IS THE RESPONSIBILITY OF THE ARCHITECT OR ENGINEER OF RECORD.
- 3. WHERE SHIM OR BUCK THICKNESS IS LESS THAN 1-1/2" WINDOW UNITS MUST BE ANCHORED THROUGH THE FRAME IN ACCORDANCE WITH MANUFACTURER'S PUBLISHED INSTALLATION INSTRUCTIONS. ANCHORS SHALL BE SECURELY FASTENED DIRECTLY INTO MASONRY, CONCRETE OR OTHER STRUCTURAL SUBSTRATE MATERIAL.
- 4. WHERE WOOD BUCK THICKNESS IS 1-1/2" OR GREATER, BUCK SHALL BE SECURELY FASTENED TO MASONRY, CONCRETE OR OTHER STRUCTURAL SUBSTRATE. WINDOW UNITS MAY BE ANCHORED THROUGH FRAME TO SECURED WOOD BUCK IN ACCORDANCE WITH MANUFACTURER'S PUBLISHED INSTALLATION INSTRUCTIONS.
- 5. WHERE 1X BUCK IS NOT USED DISSIMILAR MATERIALS MUST BE SEPARATED WITH APPROVED COATING OR MEMBRANE. SELECTION OF COATING OR MEMBRANE IS THE RESPONSIBILITY OF THE ARCHITECT OR ENGINEER OF RECORD.
- 6. BUCKS SHALL EXTEND BEYOND WINDOW INTERIOR FACE SO THAT FULL FRAME SUPPORT IS PROVIDED.
- 7. SHIM AS REQUIRED AT EACH ANCHOR LOCATION WITH LOAD BEARING SHIM. SHIM WHERE SPACE OF 1/16" OR GREATER OCCURS. MAXIMUM ALLOWABLE SHIM STACK TO BE 1/4".
- 8. SHIMS SHALL BE LOCATED, APPLIED AND MADE FROM MATERIALS AND THICKNESS CAPABLE OF SUSTAINING APPLICABLE LOADS.
- 9. WIND LOAD DURATION FACTOR Cd=1.6 WAS USED FOR WOOD ANCHOR CALCULATIONS.
- 10. FRAME MATERIAL: CO-EXTRUDED PVC FOAM.
- 11. UNITS MUST BE GLAZED PER ASTM E1300, WITH SAFETY GLAZING.
- 12. APPROVED IMPACT PROTECTIVE SYSTEM <u>IS REQUIRED</u> FOR THIS PRODUCT IN WIND BORNE DEBRIS REGIONS.
- 13. FOR ANCHORING INTO WOOD FRAMING OR 2X BUCK USE #10 WOOD SCREWS WITH SUFFICIENT LENGTH TO ACHIEVE A 1 1/4" MINIMUM EMBEDMENT INTO SUBSTRATE. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS.


- 14. FOR ANCHORING INTO MASONRY/CONCRETE USE 3/16" TAPCON WITH SUFFICIENT LENGTH TO ACHIEVE A 1 3/4" MINIMUM EMBEDMENT INTO SUBSTRATE WITH 2" MINIMUM EDGE DISTANCE. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS.
- 15. FOR ANCHORING INTO METAL STRUCTURE USE #10 SMS OR SELF DRILLING SCREWS WITH SUFFICIENT LENGTH TO ACHIEVE 3 THREADS MINIMUM BEYOND STRUCTURE INTERIOR WALL. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS.
- 16. ALL FASTENERS TO BE CORROSION RESISTANT.
- 17. INSTALLATION ANCHORS SHALL BE INSTALLED IN ACCORDANCE WITH ANCHOR MANUFACTURER'S INSTALLATION INSTRUCTIONS AND ANCHORS SHALL NOT BE USED IN SUBSTRATES WITH STRENGTHS LESS THAN THE MINIMUM STRENGTH SPECIFIED BELOW:
 - A. WOOD MINIMUM SPECIFIC GRAVITY OF G=0.42
 - B. CONCRETE MINIMUM COMPRESSIVE STRENGTH OF 3,192 PSI.
 - C. MASONRY GROUT FILLED BLOCK PER ASTM C-90 WITH Fm=2,000PSI MINIMUM.
- D. METAL STRUCTURE: STEEL 18GA, 33KSI OR ALUMINUM 6063-T5 .067" THICK MINIMUM
- 18. APPROVED CONFIGURATIONS: X, X/O, O/X, OX, XO, OX/O, XO/O, XX, XX/O, O/XX, OXX, XXO, OXX/O AND O/XXO, SEE SHEET 3.
- 19. SIDELITES ARE ASSEMBLED TO FRAME WITH #10 X 3" WOOD SCREWS LOCATED 4" FROM EACH END AND 23 1/8" MAX O.C. THEREAFTER AT JAMBS AND 4" FROM EACH END AND ONE AT MIDSPAN AT HEAD AND SILL.

SIGNED: 03/25/2022

NAN YA PLASTICS CORPORATION U.S.A. 8989 NORTH LOOP EAST HOUSTON, TX 77029 TABLE OF CONTENTS SERIES "SLPS LITE" GLAZED FIBERGLASS OUTSWING SHEET NO. DESCRIPTION SIDE-HINGED DOOR W/SIDELITES NON-IMPACT NOTES NOTES 2 ELEVATION DRAWN: DWG NO. APPROVED CONFIGURATIONS 3 - 4 08-03311 A.R. SCALE NTS DATE 09/27/18 SHEET 1 OF 17 ANCHORING LAYOUTS 5 - 6 L. ROBERTO LOMAS P.E. 7 - 15 INSTALLATION DETAILS 400 S. PALM AVE, INDIALANTIC, FL 32903 16 - 17 | COMPONENTS 434-688-0609 rllomas@lrlomaspe.com

LUIS K LOWNES TO 101889

	REVISIONS							
REV	DESCRIPTION	DATE	APPROVED					
А	REVISED TO ADD 3/4 LITE PANEL	02/10/2021	R.L.					
В	REVISED TO ADD INSTALLATION DETAILS	DATE 02/10/2021	R.L.					



SERIES SLPS OUT-SWING SIDE-HINGED DOOR W/SIDELITES

EXTERIOR VIEW
FULL LITE PANEL

97 3/16"
FRAME HEIGHT

146 7/16" FRAME WIDTH

37 3/8"
SIDELITE WIDTH

WIDTH

ACTIVE INACTIVE FIXED

SERIES SLPS OUT-SWING SIDE-HINGED DOOR W/SIDELITES

EXTERIOR VIEW

3/4 LITE PANEL

DESIGN PRESSURE RATING	IMPACT RATING
±60.0PSF	NONE

NOTES:

1. PANEL SIZE: 35 3/4" X 95 1/4"

2. D.L.O.: 25 " X 79"

HARDWARE SCHEDULE

- A. (4) STEEL 4X4 BUTT HINGE BY WENZHOU LONGTAI (PER PANEL), AT 5 3/4", 31 1/4", 56 3/4" & 82 1/4" FROM FRAME HEAD AT STILE OF ACTIVE & PASSIVE PANEL
- B. DIE CAST HANDLE SETS AT ACTIVE PANEL
- C. STAINLESS STEEL FLUSH BOLT BAR WITH KEEPERS AT ACTIVE AND PASSIVE PANEL
- D. FLUSH BOLT MECHANISM WITH KEEPERS (DIE CAST, STEEL, POM) AT PASSIVE PANEL
- E. STAINLESS STEEL DRIVE BAR WITH KEEPERS AT ACTIVE PANEL
- F. STAINLESS STEEL MULTI-POINT (3) LOCKING SYSTEM WITH KEEPERS, 8 3/8", 51 3/4" AND 90 1/8" FROM FRAME HEAD AT ACTIVE AND PASSIVE PANEL
- G. T-ASTRAGAL AT ACTIVE AND INACTIVE PANEL STILES
- H. ALUMINUM REINFORCEMENT (A) AT ASTRAGAL
- ALUMINUM MULLION REINFORCEMENT (B) AT INTEGRAL MULLION

NAN	YΑ	PLASTICS	CORPORATION	U.S.A.
		8989 NORT	H LOOP EAST	
		HOUSTON	I, TX 77029	

SERIES "SLPS LITE" GLAZED FIBERGLASS OUTSWING SIDE-HINGED DOOR W/SIDELITES NON-IMPACT ELEVATIONS

DRAWN: DWG NO. REV
A.R. 08-03311 B


SCALE NTS DATE 09/27/18 SHEET 2 OF 17

L. ROBERTO LOMAS P.E. 400 S. PALM AVE, INDIALANTIC, FL 32903 434-688-0609 rllomas@lrlomaspe.com



SIGNED: 03/25/2022






HAND ACTIVE, RIGHT HAND ACTIVE IS ALSO APPROVED.

REVISIONS

REV DESCRIPTION DATE APPROVED

A REVISED TO ADD 3/4 LITE PANEL 02/10/2021 R.L.

B REVISED TO ADD INSTALLATION DETAILS 03/14/2022 R.L.



SIGNED: 03/25/2022

NAN YA PLASTICS CORPORATION U.S.A.
8989 NORTH LOOP EAST
HOUSTON, TX 77029

SERIES "SLPS LITE" GLAZED FIBERGLASS OUTSWING SIDE-HINGED DOOR W/SIDELITES NON-IMPACT APPROVED INSTALLATION DETAILS FULL LITE PANEL


DRAWN: DWG NO. REV
A.R. 08-03311 B


SCALE NTS DATE 09/27/18 SHEET 3 OF 17

L. ROBERTO LOMAS P.E. 400 S. PALM AVE, INDIALANTIC, FL 32903 434-688-0609 rllomas@lrlomaspe.com










EXTERIOR VIEW



DOUBLE

EXTERIOR VIEW

ACTIVE

SINGLE EXTERIOR VIEW

→ 37 3/8" →|

REVISIONS

DATE

02/10/2021 R.L.

03/14/2022 R.L.


APPROVED

DESCRIPTION

REVISED TO ADD INSTALLATION DETAILS

REVISED TO ADD 3/4 LITE PANEL

DOUBLE W/SIDELITE
EXTERIOR VIEW




—— 73 5/16" —

SINGLE W/SIDELITE
EXTERIOR VIEW

ACTIVE

FIXED



SINGLE W/SIDELITE (MULL)

EXTERIOR VIEW

SIGNED: 03/25/2022

NAN YA PLASTICS CORPORATION U.S.A. 8989 NORTH LOOP EAST

HOUSTON, TX 77029

SERIES "SLPS LITE" GLAZED FIBERGLASS OUTSWING SIDE-HINGED DOOR W/SIDELITES NON-IMPACT APPROVED CONFIGURATIONS 3/4 LITE PANEL

DRAWN:		DWG NO.			REV
A.R.		08	8-03311		В
SCALE NTS	DATE 09	9/27/18	SHEET 4	OF 17	

L. ROBERTO LOMAS P.E. 400 S. PALM AVE, INDIALANTIC, FL 32903 434-688-0609 rllomas@lrlomaspe.com





Luis R. Lomas P.E. TX No.: 101889 Firm No: F-23130


NOTE:

ALL APPROVED CONFIGURATIONS ARE SHOWN AS LEFT HAND ACTIVE, RIGHT HAND ACTIVE IS ALSO APPROVED.


EXTERIOR VIEW







	REVISIONS		
REV	DESCRIPTION	DATE	APPROVED
А	REVISED TO ADD 3/4 LITE PANEL	02/10/2021	R.L.
В	REVISED TO ADD INSTALLATION DETAILS	03/14/2022	R.L.




- 1. INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.
- 2. PERIMETER AND JOINT SEALANT BY OTHERS TO BE DESIGNED IN ACCORDANCE WITH ASTM E2112


SIGNED: 03/25/2022







REVISIONS					
REV	DESCRIPTION	DATE	APPROVED		
А	REVISED TO ADD 3/4 LITE PANEL	02/10/2021	R.L.		
В	REVISED TO ADD INSTALLATION DETAILS	03/14/2022	R.L.		





- 1. INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.
- 2. PERIMETER AND JOINT SEALANT BY OTHERS TO BE DESIGNED IN ACCORDANCE WITH ASTM E2112

SIGNED: 03/25/2022










REVISIONS

REV DESCRIPTION DATE APPROVED

A REVISED TO ADD 3/4 LITE PANEL 02/10/2021 R.L.

B REVISED TO ADD INSTALLATION DETAILS 03/14/2022 R.L.





DOOR INSTALLATION DETAIL CONCRETE/MASONRY INSTALLATION

NOTES:


- 1. INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.
- 2. PERIMETER AND JOINT SEALANT BY OTHERS TO BE DESIGNED IN ACCORDANCE WITH ASTM E2112

SIGNED: 03/25/2022






	REVISIONS							
REV	DESCRIPTION	DATE	APPROVED					
А	REVISED TO ADD 3/4 LITE PANEL	02/10/2021	R.L.					
В	REVISED TO ADD INSTALLATION DETAILS	03/14/2022	R.L.					




- 1. INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.
- 2. PERIMETER AND JOINT SEALANT BY OTHERS TO BE DESIGNED IN ACCORDANCE WITH ASTM E2112


SIGNED: 03/25/2022








	REVISIONS							
REV	DESCRIPTION	DATE	APPROVED					
А	REVISED TO ADD 3/4 LITE PANEL	02/10/2021	R.L.					
В	REVISED TO ADD INSTALLATION DETAILS	03/14/2022	R.L.					





- 1. INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.
- 2. PERIMETER AND JOINT SEALANT BY OTHERS TO BE DESIGNED IN ACCORDANCE WITH ASTM E2112

SIGNED: 03/25/2022










REVISIONS

REV DESCRIPTION DATE APPROVED

A REVISED TO ADD 3/4 LITE PANEL 02/10/2021 R.L.

B REVISED TO ADD INSTALLATION DETAILS 03/14/2022 R.L.





SIDELITE INSTALLATION DETAIL CONCRETE/MASONRY INSTALLATION

NOTES:

- 1. INTERIOR AND EXTERIOR FINISHES, BY OTHERS, NOT SHOWN FOR CLARITY.
- 2. PERIMETER AND JOINT SEALANT BY OTHERS TO BE DESIGNED IN ACCORDANCE WITH ASTM E2112


SIGNED: 03/25/2022






EXTERIOR

HEAD KEEPER DETAIL




EXTERIOR


SILL KEEPER DETAIL




HOOK KEEPER DETAIL









HINGE INSTALLATION DETAIL MASONRY/CONCRETE INSTALLATION



HINGE INSTALLATION DETAIL
WOOD AND METAL INSTALLATION








SIGNED: 03/25/2022


NAN YA PLASTICS CORPORATION U.S.A. 8989 NORTH LOOP EAST HOUSTON, TX 77029


SERIES "SLPS LITE" GLAZED FIBERGLASS OUTSWING SIDE—HINGED DOOR W/SIDELITES NON—IMPACT INSTALLATION DETAILS & COMPONENTS

DRAWN:		DWG NO.					REV
A.R.			80	-03311			В
SCALE NTS	DATE O	9/27/18		SHEET 15	OF	17	


L. ROBERTO LOMAS P.E. 400 S. PALM AVE, INDIALANTIC, FL 32903 434-688-0609 rllomas@lrlomaspe.com













OUTSWING THRESHOLD ZOB4565FN
ALTERNATE



T-ASTRAGAL RIGID PVC




OUTSWING THRESHOLD FOB4565
ALTERNATE



OUTSWING THRESHOLD ZOBL4565

ALTERNATE



ULTIMATE PUSH BUTTON

ASTRAGAL

ALTERNATE

	REVISIONS							
REV	DESCRIPTION	DATE	APPROVED					
А	REVISED TO ADD 3/4 LITE PANEL	02/10/2021	R.L.					
В	REVISED TO ADD INSTALLATION DETAILS	03/14/2022	R.L.					

SIGNED: 03/25/2022

NAN YA PLASTICS CORPORATION U.S.A.
8989 NORTH LOOP EAST
HOUSTON, TX 77029

SERIES "SLPS LITE" GLAZED FIBERGLASS OUTSWING SIDE-HINGED DOOR W/SIDELITES NON-IMPACT COMPONENTS

DRAWN: DWG NO. REV
A.R. 08-03311 B

SCALE NTS DATE 09/27/18 SHEET 17 OF 17

L. ROBERTO LOMAS P.E. 400 S. PALM AVE, INDIALANTIC, FL 32903 434-688-0609 rllomas@lrlomaspe.com

