

## Product Evaluation

EC130 | 1121

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** EC-130

**Effective Date:** November 1, 2021

**Re-evaluation Date:** November 2025

**Product Name:** Reverse Classic Wall / Reverse R-Panel Steel Panels Installed over Steel Girts

**Manufacturer:** Nucor Building Group  
600 Apache Trail  
Terrell, TX 75160  
(888) 669-8165

### General Description:

The Reverse Classic Wall / Reverse R-panels are formed steel wall panels. The wall panels have 36" of coverage. The wall panels have a 1-1/4" rib height. The wall panels are manufactured from minimum 26-gauge steel with a minimum yield strength of 50 ksi.

### Limitations:

**Wall Framing:** The wall panels must be installed over open steel girts. The steel girts are minimum 16-gauge steel.

**New Wall Framing Attachment:** The wall framing must meet or exceed the design pressure requirements of the IRC or IBC and must be installed as required for resistance to wind loads.

**Design Wind Pressures:** The design pressure load resistance must be as specified in Table 1 and Table 2. Design pressures are based on a minimum triple span with equal length spans and a maximum deflection of span/60.

**Table 1**

Attachment of Minimum 24-gauge Reverse Classic Wall/Reverse R-Panel Wall Panels to Steel Girts

Span (ft)	Design Pressure (psf)		Attachment of Panel to Steel Girts
	Gr 50	Gr 80	
3	-75	-75	Fasteners at 12"-12"-12"
3.5	-64	-64	Fasteners at 12"-12"-12"
4	-56	-56	Fasteners at 12"-12"-12"
4.5	-50	-50	Fasteners at 12"-12"-12"
5	-45	-45	Fasteners at 12"-12"-12"
5.5	-41	-41	Fasteners at 12"-12"-12"
6	-38	-38	Fasteners at 12"-12"-12"
6.5	-35	-35	Fasteners at 12"-12"-12"
7	-30	-32	Fasteners at 12"-12"-12"
7.5	-26	-30	Fasteners at 12"-12"-12"

**Table 2**

Attachment of Minimum 26-gauge Reverse Classic Wall/Reverse R-Panel Wall Panels to Steel Girts

Span (ft)	Design Pressure (psf)		Attachment of Panel to Steel Girts
	Gr 50	Gr 80	
3	-72	-72	Fasteners at 12"-12"-12"
3.5	-62	-62	Fasteners at 12"-12"-12"
4	-54	-54	Fasteners at 12"-12"-12"
4.5	-48	-48	Fasteners at 12"-12"-12"
5	-43	-43	Fasteners at 12"-12"-12"
5.5	-38	-40	Fasteners at 12"-12"-12"
6	-32	-36	Fasteners at 12"-12"-12"
6.5	-27	-32	Fasteners at 12"-12"-12"
7	-24	-28	Fasteners at 12"-12"-12"
7.5	-21	-24	Fasteners at 12"-12"-12"

**Installation:**

**General:** The wall panels must be installed in accordance with the manufacturer's recommended installation instructions and this evaluation report.

**Steel Girts:** The steel girts are minimum 16-gauge steel.

**Attachment of Steel Panels to the Steel Girts:** The steel panels must be secured to the open steel girts with minimum No. 12-14 x 1-1/4" long HWH self-driller screws manufactured by Atlas. A line of fasteners must be located along each steel girt. The spacing of the fasteners must be as specified in Table 1 and Table 2. The fasteners must be long enough to ensure a minimum penetration of 3 pitches of thread below the steel girts.

**Panel Side Laps:** The panels are stitched together with minimum 1/4-14 x 7/8" Lap Tek screws. The fasteners must be spaced a maximum of 20" on center along the length of the side lap.

**Panel Ends and End Laps to the Steel Girts:** The steel panels must be secured to the open steel girts with minimum No. 12-14 x 1-1/4" long HWH self-driller screws manufactured by Atlas. A line of fasteners must be located along the steel girt. The spacing of the fasteners must be as specified in Table 1 and Table 2. The fasteners must be long enough to ensure a minimum penetration of 3 pitches of thread below the steel girts.

**Panel Ends and End Laps to the Steel Girts:** The steel panels must be secured to the open steel girts with minimum No. 12-14 x 1-1/4" long HWH self-driller screws manufactured by Atlas. A line of fasteners must be located along the steel girt. The spacing of the fasteners must be as specified in Table 1 and Table 2. The fasteners must be long enough to ensure a minimum penetration of 3 pitches of thread below the steel girts.

**Trims, Closures, and Accessories:** Trim, closure, and accessory components must be installed as required by the manufacturer.

**Note:** Keep the manufacturer's installation instructions available on the job site during the installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.