

## Product Evaluation

EC98 | 0422

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** EC-98

**Effective Date:** April 1, 2022

**Re-evaluation Date:** April 2026

**Product Name:** Minimum 24-gauge Steel Artisan L12 Wall Panels Installed over Steel Girts

**Manufacturer:** Metal Building Components, Inc. (MBCI), L.P., a division of NCI, L.P.  
14031 West Hardy  
Houston, TX 77060  
(281) 445-8555

### General Description:

The Artisan L12 wall panels are minimum 24-gauge steel panels. The steel wall panels have a maximum 12" of coverage. The steel wall panels are 1" deep. The steel wall panels are Galvalume steel with a minimum yield strength of 50,000 psi.

### Limitations:

**Wall Framing:** The steel wall panels must be installed over open steel girts.

**New Wall Framing Attachment:** The wall framing must meet or exceed the wind pressure requirements of the IRC or IBC and must be installed as required for resistance to wind loads.

**Design Wind Pressures:** The design pressure load resistance must be as specified in Table 1.

**Table 1**  
Attachment of Minimum 24-gauge Steel Artisan L12 Wall Panels to Steel Girts

| System | Design Wind Pressure | Girts                                | Attachment of Panel to Steel Girts  |
|--------|----------------------|--------------------------------------|-------------------------------------|
| 1      | -50.0 psf            | Minimum 16-gauge;<br>4'-0" on center | #12-14 x 1" HWH self-driller screws |
| 2      | -85.0 psf            | Minimum 16-gauge;<br>1'-0" on center | #12-14 x 1" HWH self-driller screws |

**Installation:**

**General:** The steel wall panels must be installed in accordance with the manufacturer’s recommended installation instructions and this evaluation report.

**Steel Girts:** The minimum thickness of the steel and the maximum on center spacing of the girts must be as specified in Table 1.

**Attachment of Steel Wall Panels to the Steel Girts:** Secure the panels to the steel girts with #12-14 x 1" HWH self-driller screws, manufactured by SFS. One (1) fastener is required at each girt. The panels are secured together with one (1) 1/4-14 x 7/8" Lap Tek self-driller screw, manufactured by SFS, at 24" on center. The fasteners must be long enough to ensure a minimum penetration of 3 pitches of thread below the girts.

**Panel Ends and End Laps:** Secure the panels to the steel girts with #12-14 x 1" HWH self-driller screws, manufactured by SFS. One (1) fastener is required at each girt. The panels are secured together with one (1) 1/4-14 x 7/8" Lap Tek self-driller screw, manufactured by SFS, at 24" on center. The fasteners must be long enough to ensure a minimum penetration of 3 pitches of thread below the girts.

**Trims, Closures, and Accessories:** Components, such as trims, closures, and accessories must be installed as required by the manufacturer.

**Note:** Keep the manufacturer’s installation instructions available on the job site during the installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.