

2

1.95" THICK, 1# DENSITY

TONGUE AND GROOVE JOINTS.

VIEW "D'

MIN. 80 KSI.

4" TALL TAPER STRUT.
MIN. 0.062" GALV. STEEL.

EXPANDED POLYSTYRENE FOAM


INSULATION LAMINATED TO BOTH

EXTERIOR AND INTERIOR SKINS.

MDDELS 27 GA FLUSH 27 GA LONG 27 GA SHORT CLOPAY 4300, HDG 4301, HDGF 4310, HDGL 67, 67G, 6203 66, 66G, 6200 68, 6201 HOLMES IDEAL SP200 SF200 SE500

IN THE CASE OF GYPSUM WALLBOARD LOCATED AT OR NEAR THE DOOR OPENING LOCATION THERE ARE TWO ACCEPTABLE ALTERNATIVES:

- 1) THE WALLBOARD CAN BE CUT AWAY FROM THE DOOR OPENING AND 2X6 SOUTHERN YELLOW PINE WOOD JAMBS MOUNTED DIRECTLY TO THE SUPPORTING STRUCTURE TO CREATE THE MOUNTING SURFACE. ALTERNATIVELY, THE BRACKETS MAY BE ATTACHED DIRECTLY TO THE SUPPORTING STRUCTURE. SEE DETAIL BELOW. THE CENTER OF SCREW HOLE MUST BE AT LEAST ½" FROM BOTH EDGES FOR A 5/16" LAG SCREW.
- 2) IF THE WALLBOARD IS NOT CUT AWAY TO EXPOSE THE UNDERLYING STRUCTURE (WOOD FRAMING MEMBERS), A 2X6 SOUTHERN YELLOW PINE WOOD BUCK OVER SHALL BE INSTALLED THE WALLBOARD FRAMING THE OPENING USING THE JAMB ATTACHMENT FASTENERS LISTED BELOW. HOWEVER, THE JAMB ATTACHMENT FASTENERS MUST BE OF A SUFFICIENT INCREASED LENGTH TO ACCOUNT FOR THE THICKNESS OF THE WALLBOARD TO ENSURE PROPER FASTENER EMBEDMENT INTO THE STRUCTURAL FRAMING MEMBERS OF THE SUPPORTING STRUCTURE.



#14x5/8" SHEET METAL SCREWS

1/4"x3/4" SELF
TAPPING SCREWS.

14 GA. END HINGES
VIEW "B"

3

18 GA. (MIN.) INTERMEDIATE HINGE VIEW "C"

## PREPARATION OF JAMBS BY OTHERS.

VERTICAL JAMB ATTACHMENT (WOOD FRAME BUILDINGS): 3/8"x3" LAG SCREWS ON 17" CENTERS. 1-1/8" O.D. WASHER REQUIRED. LAG SCREWS MAY BE COUNTERSUNK (BUT NOT REQUIRED) TO PROVIDE A FLUSH MOUNTING SURFACE. HORIZONTAL JAMBS DO NOT TRANSFER LOAD.

VERTICAL JAMB ATTACHMENT (C-90 BLOCK OR 2,000 PSI MIN. CONCRETE COLUMN): 3/8"x3" SLEEVE ANCHOR BOLTS ON 10" CENTERS (2,000 PSI MIN. CONCRETE). WASHERS INCLUDED WITH SLEEVE ANCHORS.

1/4"x3" TAPCON SCREWS ON 8" CENTERS (2,000 PSI MIN. CONCRETE) OR 5" CENTERS (C-90 BLOCK), 1" O.D. WASHERS REQUIRED WITH TAPCONS.
ANCHORS MAY BE COUNTERSUNK (BUT NOT REQUIRED) TO PROVIDE A FLUSH MOUNTING SURFACE. HORIZONTAL JAMBS DO NOT TRANSFER LOAD.

OTHER JAMB CONFIGURATIONS: REFER TO DASMA TDS-161. A LICENSED DESIGN PROFESSIONAL MAY ALSO BE EMPLOYED TO APPROVE ALTERNATE FASTENERS AND/OR JAMB CONFIGURATIONS.

DESIGN ENGINEER: MARK WESTERFIELD, P.E.

FLORIDA P.E. #48495, NC P.E. #23832, TEXAS P.E. #91513

27 GA (0.016" MIN.) EXTERIOR STEEL SKIN WITH G-40 MIN. GALV. BAKED-ON POLYESTER PAINTED TOP COAT APPLIED TO BOTH SIDES OF STEEL SKIN.

— SILICONE FILLED CHANNEL SEPARATES FRONT AND BACK SKIN OF DOOR.

TOP SECTION WITH LITES: (2) 18 GA. GALV. STEEL TOP ROLLER BRACKETS (2-7/16" × 3-3/4"). EACH BRACKET ATTACHED W/(4) #14×5/8" SHEET METAL SCREWS. SOLID TOP SECTION: (2) 12 GA. GALV. STEEL TOP ROLLER BRACKETS (2-1/2" × 5-3/8"). EACH BRACKET ATTACHED W/(4) #14×5/8" SHEET METAL SCREWS. ADJUSTABLE SLIDE ATTACHED TO TOP BRACKET WITH (2) 1/4"x1/2" BOLTS AND NUTS PER BRACKET.

27 GA. (0.016" MIN.) INTERIOR STEEL SKIN (DRAWING QUALITY) WITH G-40 MIN. GALV., BAKED-ON PRIMER AND A BAKED-ON POLYESTER PAINTED TOP COAT APPLIED TO BOTH SIDES OF STEEL SKIN.

14 GA. GALV. ROLLER HINGE. EACH HINGE FASTENED TO END STILES WITH (4) #14x5/8" SHEET METAL AND (2) 1/4"x3/4" SELF TAPPING SCREWS. SEE VIEW "B".

3" TALL X 20 GA. GALV. STEEL U-BARS. ONE U-BAR AT THE TOP OF EACH SECTION. ATTACH WITH TWO 1/4"x3/4" SELF TAPPING SCREWS PER HINGE.

ONE 4" T-STRUT PER SECTION (SEE VIEW "D"). EACH T-STRUT ATTACHED AT EACH HINGE LOCATION WITH (2) 1/4"x3/4" SELF TAPPING SCREWS.

13 GA. GALV. STEEL BOTTOM BRACKET ATTACHED WITH (2) #14x5/8" SHEET METAL SCREWS.
-ALUMINUM EXTRUSION & VINYL WEATHERSTRIP.

## SECTION A-A (SIDE VIEW)

MANUFACTURING PRODUCT CODE DSIE-1F171 DESIGN LOADS: +46.0 P.S.F. & -50.0 P.S.F. PART NO.: N/A TEST LOADS: +69.0 P.S.F. & -75.0 P.S.F. WINDLOAD RATING 8585 Duke Boulevard Mason, OH 45040 USA Tel. No. 513-770-4800 Fax No. 513-770-4853 Unless Stated Otherwise Globay TOLERANCES are CORPORATION  $.0 = \pm .031$ DESCRIPTION: 2" EPS INS. DOORS TO 18'2" (SEE TABLE FOR MODELS)  $.00 = \pm .015$  $.000 = \pm .005$ DATE: 11/8/12 | SCALE: NTS DWG. T DRAWN BY: SH  $.0000 = \pm .001$ DATE: 11/9/12 SHEET 2 OF 3 SIZE B Degrees =  $\pm 1/2$ CHECKED BY: SH Unless Stated Otherwise DIMENSIONS ARE IN INCHES. DWG. NO.: 104752 VER: TDI

2

•

