



Product Evaluation

RC555| 1017

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: RC-555

Effective Date: October 1, 2017

Re-evaluation Date: October 2021

Product Name: 1.75 Snap Lock 24-gauge Steel Roof Panels Installed Over a Plywood Deck

Manufacturer: Sunlast Metal
2120 SW Poma Drive
Palm City, Florida 34990
(954) 931-9606

General Description:

The 1.75 Snap Lock steel roof panel is a minimum 24-gauge steel panel. The panel has a 1-3/4" rib height. The panels have a maximum coverage of 18".

Limitations:

Design Wind Pressures: The design wind pressure uplift resistance is specified in Table 1.

Roof Framing: Roof framing (rafters or trusses) must not exceed 24" on center.

Roof Deck: Install the metal roof panels over minimum 15/32" plywood.

Roof Deck Attachment: The roof deck must be secured to the roof framing to resist the required wind uplift design pressures.

Installation Over an Existing Roof Covering: Installation over an existing roof covering is limited to a maximum of one existing layer of composition shingles, wood shingles or shakes, built-up roofing, or roll roofing. The existing roof deck must be minimum 15/32" plywood. Note: Inspection of the existing roof deck must be made before installing the roof panels. The condition of the existing roof deck must be acceptable to receive the roof panels before the roof panel installation can proceed.

Roof Slope: The metal roof panels may be installed on roofs with a roof slope as low as 2:12.

Installation:

Panels: The metal roof panels must be attached to the plywood deck in accordance with Table 1 and the manufacturer’s recommended installation instructions.

Table 1
Attachment of 1.75 Snap Lock Steel Roof Panels to Plywood Deck

Wind Pressure	Clip Spacing	Fasteners per Clip
-114.25 psf	16" on center	Two fasteners
-156.75 psf	8" on center	Two fasteners

Underlayment: A minimum of one layer of No. 30 (Type II) asphalt felt must be used. The underlayment used must comply with one or more of the following: ASTM D 226, ASTM D 4869, or ASTM D 1970. The felt must be installed with minimum 4" side laps and minimum 6" end laps. The underlayment must be applied with corrosion-resistant fasteners in accordance with manufacturer’s installation instructions. Fasteners must be applied along the overlaps not farther apart than 36" on center.

Attachment of Panels to Roof Deck: The panels must be secured to the deck in accordance with Table 1 with 1-7/8" tall x 3-1/2" long x 2.08" wide x 0.050" galvanized steel clips. Each clip is secured to the roof deck with two minimum No. 10 x 1" Pancake Head Type A screws. The fasteners must be long enough to penetrate completely through the deck.

Panel Ends: Minimum No. 10 x 1" Pancake Head screws located 3" on center.

Panel Edges: Minimum No. 10 x 1" Pancake Head screws located 3" on center.

Trim: Components such as eave trim, rake trim, hip trim, and valley trim must be installed as required by the manufacturer.

Note: Keep the manufacturer’s installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.