

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

RC557 | 0221

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: RC-557

Effective Date:February 1, 2021Re-evaluation Date:February 2025

Product Name: Deep Deck Aluminum Roof Panels Installed over Steel Purlins

Manufacturer: Berridge Manufacturing Company 6515 Fratt Road San Antonio, TX 78218 (210) 650-3050

General Description:

The Deep Deck aluminum roof panels are formed metal roofing panels. The roof panels have 36" of coverage. The roof panels have a 1-1/2" rib height. The roof panels are manufactured from 0.032" thick 3105 H14 aluminum.

Limitations:

Roof Framing: The roof panels must be installed over open steel purlins.

New Roof Framing Attachment: The roof framing must meet or exceed the uplift requirements of the IRC or IBC and must be installed as required for resistance to wind loads.

Design Wind Pressures: The design pressure uplift load resistance must be as specified in Table 1.

Roof Slope: The roof panels may be installed on roofs with a roof slope as low as 3:12.

Installation Over an Existing Roof Covering: Not permitted.

Table 1

Attachment of 0.032" Aluminum Deep Deck Roof Panels to Steel Purlins

Design Wind Pressure	Purlins	Attachment of Panel to Steel Purlins
-119.65 psf	Minimum 16 gauge; 4'-0" on center	Fasteners at 7.2" on center

Installation:

General: The roof panels must be installed in accordance with the manufacturer's recommended installation instructions and this evaluation report.

Steel Purlins: Berridge Manufacturing Company steel "CEE" or "ZEE" purlins. The minimum thickness of the steel and the maximum spacing of the purlins must be as specified in Table 1.

Attachment of Metal Roof Panels to the Steel Purlins: The roof panels must be secured to the steel purlins with No. 12-14 x 1" Blazer Flange-Seal head screws with an EPDM washer manufactured by Triangle Fastener Corporation. A line of fasteners must be located along each steel purlin. The spacing of the fasteners must be as specified in Table 1. Two (2) fasteners are required at each location. The fasteners must be long enough to ensure a minimum penetration of 3 pitches of thread below the steel purlins.

Panel Side Laps: The panels must overlap one corrugation. The panels are stitched together with minimum $1/4-14 \times 7/8$ " Blazer Flange-Seal head screws with an EPDM washer manufactured by Triangle Fastener Corporation. The fasteners must be spaced 18" on center along the length of the side lap.

Panel Ends: Minimum No. 12-14 x 1" Blazer Flange-Seal head screws with an EPDM washer manufactured by Triangle Fastener Corporation. A line of fasteners must be located along the steel purlin. The spacing of the fasteners must be as specified in Table 1. Two (2) fasteners required at each location. The fasteners must be long enough to ensure a minimum penetration of 3 pitches of thread below the steel purlins.

Trims, Closures, and Accessories: Components, such as the eave trim, rake trim, ridge trim, hip trim, and valley trim shall be installed as required by the manufacturer.

Note: Keep the manufacturer's installation instructions available on the job site during the installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.