

## Product Evaluation

WIN1022 | 1020

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-1022

**Effective Date:** October 1, 2020

**Re-evaluation Date:** October 2024

**Product Name:** Series 42-19 Vinyl Casement Windows, Fin Installation, Non-Impact Resistant

**Manufacturer:** Simonton Windows & Doors by Ply Gem  
5020 Weston Pkwy, Ste. 300  
Cary, NC 27513  
(800) 542-9118 ext. 413596

**Marketed As:** ProFinish Brickmould 600  
PerfeXion BM 600

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 42-19 Vinyl Casement Windows	R-PG60 (36 x 72)-C	+60 / -60 psf
2	Series 42-19 Vinyl Casement Windows; Triple Mulled	R-PG25 (101 x 63)-C	+25 / -25 psf
3	Series 42-19 Vinyl Casement Windows; Triple Mulled	R-PG45 (107 x 72)-C	+45 / -45 psf

**Product Dimensions:**

System	Overall Size	Operable Sash Size
1	36" x 72"	34-1/4" x 70-1/4"
2	101" x 63"	31-3/8" x 61-1/8" (3)
3	106-1/2" x 72"	33-3/4" x 70-1/8"

**Product Identification (Certification Label on Window):**

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	SIM-1 or SIM-2
	Product Name	42-19 CASEMENT
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08
2-3	Certification Agency	AAMA
	Manufacturer's Name or Code Name	SIM-1 or SIM-2
	Product Name	42-19 CASEMENT TRIPLE (T-MULL)
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

**Impact Resistance:**

System	Impact Resistant	Requirement
1-3	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System		
1-3	Type of Installation	Nail Fin Installation
	Wall Framing	Spruce-Pine-Fir
	Fasteners	No. 6 steel fasteners (Nail Fin) No. 8 x 3" steel fasteners (Tie Bar Guides)
	Fastener Location/Spacing	Nail Fin: At each corner and 8-1/2" on center along the perimeter Tie Bar Guides: One fastener at each guide
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.