

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

Product Evaluation

WIN1051 | 0322

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1051 **Effective Date:** March 1, 2022

Re-evaluation Date: July 2025

Product Name: Series 700 Vinyl Shaped Fixed Windows, Fin and Frame Installation, Non-Impact

Resistant

Manufacturer: Atrium Windows & Doors

300 Welcome Center Blvd.

Welcome, NC 27374

(800) 542-9118 ext. 413596

Marketed As: 720 Series

750 Series 755 Series

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 700 Vinyl Shaped Fixed Windows; O	CW-PG50 (72 x 72)-FW FW-C50 (72 x 72)	+50 / -50 psf

Product Dimensions:

System	Overall Size	Fixed Sash Daylight Opening Size
1	72" x 72"	67" x 67"

Product Identification (Certification Label on Window):

System			
	Certification Agency	NAMI	
	Manufacturer's Name or Code Name	Atrium Companies (Welcome, NC)	
1	Product Name	700 Shaped Picture Window;	
		Fin & Finless Installation	
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08,05	

Impact Resistance:

System	Impact Resistant	Requirement
1	INO.	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation (One of the Following):

Nail Fin Installation: The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing using a nailing fin. The nailing fin is secured to the wall framing using minimum No. 8 PH screws. Locate the screws approximately 2" from each corner and 8" on center thereafter along the perimeter. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Frame Installation: The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing using minimum No. $10 \times 2-1/2$ " PH screws spaced approximately 6" from each corner and 20" on center thereafter along the head, sill, and side jambs. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.