

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

WIN1120 | 0922

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 1-800-248-6032.

Evaluation ID: WIN-1120 **Effective Date:** September 1, 2022

Re-evaluation Date: August 2025

Product Name: Series 95 Aluminum Single Hung Window, Fin Installation, Non-Impact Resistant

Manufacturer: Croft, LLC

P.O. Box 826

McComb, MS 39649 (601) 684-6121

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 95 Aluminum Single Hung Windows	R-PG40 (36 x 72)- H	+40 / -40 psf

Product Dimensions:

System	Overall	Operable	Fixed Glass Daylight
	Size	Sash Size	Opening Size
1	36" x 72"	34-1/2" x 36-1/2"	32-1/2" x 33-1/4"

Product Identification (Certification Label on Window):

System		
1	Certification agency	AAMA
	Manufacturer's name or code name	CRO-1
	Product name	95-SH
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Compliance: The products comply with AAMA/WDMA/CSA 101/I.S.2/A440-17 as referenced in the 2018 IRC and 2018 IBC.

Impact Resistance:

System	Impact resistant	Requirement
1	No	These products have not been tested for windborne debris resistance. An impact protection system is required when installing this product in areas where windborne debris protection is required.

Installation:

Use minimum Spruce-Pine-Fir dimension lumber for the wall framing. Secure the window to the wall framing using the nailing fin of the window with minimum No. 8 Philips flat head screws. The fasteners must be placed approximately 3" from each corner and 12" on center along the perimeter of the window. Minimum 1" x 1" wood stops are placed over the nailing fin along the perimeter of the window and secured through the nailing fin and into the wall framing with minimum No. 8 x 3" Philips flat head screws spaced approximately 24" on center along the perimeter of the window. The fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.