

Product Evaluation

WIN1129 | 1020

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1129

Effective Date: October 1, 2020

Re-evaluation Date: October 2024

Product Name: Ultimate Aluminum Clad Wood Casement Windows, Narrow Frame and Full Frame, Frame Installation, Non-Impact Resistant

Manufacturer: Marvin
Hwy 11 West
Warroad, MN 56763
(800) 346-5044

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Ultimate Clad Wood Casement Windows, Narrow & Full Frame	CW-PG50 (36 x 96.12)	+50 / -50 psf
2	Ultimate Clad Wood Casement Windows, Narrow & Full Frame	LC-PG50 (44 x 71.12)	+50 / -50 psf
3	Ultimate Clad Wood Casement Windows, Narrow & Full Frame	LC-PG50 (40 x 91.13)	+50 / -50 psf
4	Ultimate Clad Wood Casement Windows, Narrow & Full Frame	CW-PG40 (36 x 102)	+40 / -40 psf
5	Ultimate Clad Wood Casement Windows, Narrow & Full Frame	CW-PG40 (40 x 96.12)	+40 / -40 psf

General Description (continued):

System	Description	Label Rating	Design Pressure Rating
6	Ultimate Clad Wood Casement Windows, Narrow & Full Frame	LC-PG40 (44 x 91.12)	+40 / -40 psf

Product Dimensions:

System	Overall Size	Operable Sash Size
1	36" x 96-1/8"	34-5/16" x 94-7/16"
2	44" x 71-1/8"	42-5/16" x 69-7/16"
3	40" x 91-1/8"	38-5/16" x 89-7/16"
4	36" x 102"	34-3/8" x 100-3/8"
5	40" x 96-1/8"	38-5/16" x 94-7/16"
6	44" x 91-1/8"	42-5/16" x 89-7/16"

Product Identification (Certification Label on Window):

System		
1-6	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Marvin
	Product Name	UL CSMNT or UL CSMNT NF
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

Impact Resistance:

System	Impact Resistant	Requirement
1-6	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1-6	Type of Installation	Screw Through Frame
	Wall Framing	Spruce-Pine-Fir
	Fasteners	No. 8 x 3" screws
	Fastener Location/Spacing	Side Jamb: 4" from each corner and 15" on center Sill: through each side of the operator base hardware (System 2, 4-6)
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.