

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

# **Product Evaluation**

#### WIN1208 | 0423

**Engineering Services Program** 

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-1208 **Effective Date:** April 1, 2023

**Re-evaluation Date:** January 2026

Product Name: Series 8300/8700/1300/1600/3201/3500/40/80/3000/6000 Vinyl Fixed Windows,

Non-Impact Resistant

Manufacturer: Atrium Companies, Inc.

300 Welcome Center Blvd.

Welcome, NC 27374

(800) 542-9118 ext. 413596

**General Description:** 

System	Description	Label Rating	Design Pressure Rating
1	Vinyl Fixed Window; O	R-PG50 (48 x 84)-FW FW-R50 (48 x 84)	+50 / -50 psf

#### **Product Dimensions:**

System	Overall Size	Fixed Sash Daylight Opening Size
1	48" x 84"	43-5/8" x 79-5/8"

## **Product Identification (Certification Label on Window):**

System		
	Certification Agency	NAMI
	Manufacturer's Name	Atrium Companies
1	Product Name	8300/8700/1300/1600/3201/3500/40/80/3000/6000
		Vinyl Fixed Window w. Finless Installation
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05,08,11,17

### **Impact Resistance:**

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

### **Installation:**

System			
	Type of Installation	Frame Installation	
	Wall Framing	Spruce-Pine-Fir dimension lumber	
1	Fasteners	No. 10 x 2-1/2" wood screws	
'	Fastener Location/Spacing	Head/Sill: 6" from each corner and at the midpoint	
		Jambs: 6" from each corner and 18" on center	
	Fastener Penetration	Minimum of 1-1/2" into the wall framing	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.