

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

WIN1291 | 0920

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1291 **Effective Date:** September 1, 2020

Re-evaluation Date: September 2024

Product Name: Ultimate Prime Wood and Aluminum Clad Wood Narrow Frame Push Out

Casement Windows, Non-Impact Resistant

Manufacturer: Marvin

P.O. Box 100 Highway 11 West Warroad, MN 56763 (800) 346-5044

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Clad Wood Narrow Frame Push Out Casement Windows,	LC-PG50 (36 x 71.12)	+50 / -50 psf
2	Clad Wood Narrow Frame Push Out Casement Windows,	LC-PG50 (36 x 96.12)	+50 / -50 psf
3	Clad Wood Narrow Frame Push Out Casement Windows,	LC-PG35 (40 x 91.12)	+35 / -35 psf
4	Prime Wood Narrow Frame Push Out Casement Windows,	CW-PG50 (36 x 71.13)	+50 / -50 psf

General Description (Continued):

System	Description	Label Rating	Design Pressure Rating
5	Prime Wood Narrow Frame Push Out Casement Windows,	CW-PG35 (36 x 96.13)	+35 / -35 psf
6	Prime Wood Narrow Frame Push Out Casement Windows,	CW-PG35 (40 x 91.13)	+35 / -35 psf

Product Dimensions:

System	Overall Size	Operable Sash Size
1	36" x 71-1/2"	34-5/16" x 69-7/16"
2	36" x 96-1/8"	34-5/16" x 94-7/16"
3	40" x 91-1/8"	38-5/16" x 89-7/16"
4	36" x 71-1/8"	34-3/8" x 69-3/8"
5	36" x 96-1/8"	34-3/4" x 94-3/8"
6	40" x 91-1/8"	38-3/8" x 89-3/8"

Product Identification (Certification Label on Window):

System		
1-3	Certification Agency	WDMA
	Manufacturer's Name or Code Name Marvin	
	Product Name	UL CSMNT PO
1-5		OR
		UL CSMENT NF PO
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11,17
	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Marvin
4-6	Product Name UL WD CSMNT PO	
		OR
		UL WD CSMNT NF PO
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11,17

Impact Resistance:

System	Impact Resistant	Requirement
1-6	No	Provide an impact protective system when installing the
	140	product in areas that require windborne debris protection.

Installation:

System			
	Type of Installation	Nail Fin	
	Wall Framing	Spruce-Pine-Fir dimension lumber	
	Fasteners	1-1/2" galvanized smooth shank roofing nails	
1	Fastener Location/Spacing	6" from each corner and 8" on center along the perimeter	
	Fastener Penetration	Minimum of 1-7/16" into the wall framing members	
	Type of Installation	Screw Through Frame	
2-3	Wall Framing	Spruce-Pine-Fir dimension lumber	
	Fasteners	No. 8 x 3" screws	
	Fastener Location/Spacing	4" from each corner and 15" on center along the side jambs	
	Fastener Penetration	Minimum of 1-1/4" into the wall framing members	
	Type of Installation	Screw Through Frame	
	Wall Framing	Spruce-Pine-Fir dimension lumber	
4-6	Fasteners	No. 8 x 3" screws along the head and sill; No. 8 x $3-1/2$ " along the sill.	
	Fastener Location/Spacing	4" from each corner and 15" on center along the perimeter	
	Fastener Penetration	Minimum of 1-1/4" into the wall framing members	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.