

Product Evaluation

WIN1299 | 0523

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1299

Effective Date: May 1, 2023

Re-evaluation Date: May 2027

Product Name: Ultimate Prime Wood and Aluminum Clad Wood Casement Windows, Fin and Frame Installation, Impact Resistant

Manufacturer: Marvin
Highway 11 West
Warroad, MN 56763
(218) 386-4021

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Ultimate Clad Wood Casement Windows	CW-PG65 (36 x 95.12) Missile Level D	+65 / -65 psf
2	Ultimate Wood Casement Windows	CW-PG65 (36 x 96.06) Missile Level D	+65 / -65 psf
3	Ultimate Clad Wood Casement Windows	CW-PG65 (36 x 83.12) Missile Level D	+65 / -65 psf
4	Ultimate Wood Casement Windows	CW-PG65 (36 x 84.06) Missile Level D	+65 / -65 psf

Product Dimensions:

System	Overall Size	Operable Sash Size
1	36" x 95-1/8"	34-5/16" x 93-7/16"
2	36" x 96-1/16"	34-5/16" x 93-7/16"
3	36" x 83-1/8"	34-5/16" x 81-7/16"
4	36" x 84-1/16"	34-5/16" x 81-7/16"

Product Identification (Certification Label on Window):

System		
1, 3	Certification Agency	WDMA
	Manufacturer's Name	Marvin
	Product Name	UL CSMNT IZ3
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11,17 (System 1) ASTM E1886-13a/E1996-17 AAMA/WDMA/CSA 101/I.S.2/A440-11,17 (System 3) ASTM E1886-13a/E1996-14a Missile Level D
2, 4	Certification Agency	WDMA
	Manufacturer's Name	Marvin
	Product Name	UL WD CSMNT IZ3
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11,17 ASTM E1886-13a/E1996-17; Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1-4	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation (One of the following):

Screws Through Frame (System 1-4): The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing with minimum No. 8 x 3" screws. Locate the fasteners approximately 6" from each corner and 15" along all sides. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Aluminum Nailing Fin (System 1, 3): The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing using the aluminum nailing fin with minimum 2" long, 12-gauge smooth shank roofing nails. Locate the fasteners approximately 6" from each corner and 8" along the perimeter of the window. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Structural Brackets (System 1-4): The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing with structural brackets (minimum 19-gauge x 1-1/2" x 4-1/2" galvanized steel). Secure the brackets to the window frame with two No. 8 x 5/8" screws and to the wall framing with four (4) No. 8 x 3" screws (two (2) on each side of the wall framing). Locate the brackets approximately 6" from each corner and 13" (max.) on center along all sides. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.