

## Product Evaluation

WIN1336 | 0519

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 1-800-248-6032.

**Evaluation ID:** WIN-1336

**Effective Date:** May 1, 2019

**Re-evaluation Date:** May 2023

**Product Name:** Aluminum Clad Wood Lincoln Fit Casement Windows, Frame Installation, Non-Impact Resistant

**Manufacturer:** Lincoln Wood Products, Inc.  
1400 West Taylor Street  
Merrill, Wisconsin 54452  
(715) 536-2461

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Aluminum Clad Wood Lincoln Fit Casement Windows	R-PG40 42 x 96-C	+40 / -40 psf

### Product Dimensions:

System	Overall Size	Sash Size
1	42" x 96"	40" x 94"

**Product Identification (Certification Label on Window):**

System		
1	Certification agency	AAMA
	Manufacturer's name or code name	LN-1
	Product name	Clad Lincoln Fit Casement
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

**Impact Resistance:**

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:****Frame Installation:**

The wood framing members must be minimum Spruce-Pine Fir dimension lumber. The window assembly is secured to the wall framing using minimum No. 8 x 3" PFH screws. The fasteners must be through the side jamb and into the wall framing spaced approximately 3"-4" from each side corner and one at the midspan. Cover the gap between the window frame and wall framing using minimum 5/8" x 1-3/4" wood strips. The wood strip must be secured to the wall framing using minimum 3/16" crown x 1-1/8" long staples spaced approximately 8" on center. The fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.