

Product Evaluation

WIN1632 | 0521

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1632

Effective Date: May 1, 2021

Re-evaluation Date: May 2025

Product Name: Prime Wood Horizontal Sliding Windows, Brickmould Installation, Non-Impact Resistant

Manufacturer: Lincoln Wood Products, Inc.
1400 W. Taylor Street
Merrill, WI 54452
(715) 536-2461

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Prime Wood Horizontal Sliding Windows; XX	HS-C35 (72 x 60)	+35 / -35 psf

Product Dimensions:

System	Overall Size	Operable Sash Size	Fixed Sash Daylight Opening Size
1	71-7/8" x 59-1/4"	35-5/8" x 56-1/2"	31-3/16" x 53-3/16"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	LN-1
	Product Name	Prime Glider
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A44-05

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing using the brickmould. Secure the brickmould to the window frame with 2-1/2" wire brads spaced approximately 8-12" on center and secure to the wall framing with No. 8 x 3" screws spaced approximately 10-12" on center. The brickmould was silicone sealed and secured to the sill with one No. 8 x 3" screw. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.