

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

Product Evaluation

WIN1781 | 0422

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1781 **Effective Date:** April 1, 2022

Re-evaluation Date: March 2025

Product Name: Series 6701 NC/ 6702 Rep Vinyl Double Hung Windows, Non-Impact Resistant

Manufacturer: Window Mart

5760 Albert Pike Royal, AR 71968 (888) 283-6278

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 6701 NC/ 6702 Rep Vinyl Double Hung Windows; X/X	H-R50 (48 x 72)	+50 / -50 psf

Product Dimensions:

System	Overall Size	Top Sash Size	Bottom Sash Size
1	48" x 72"	34-5/8" x 43-3/8"	35-5/8" x 44-3/8"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 588-194
	Product Name	6701 NC / 6702 Rep Double Hung
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05

Impact Resistance:

Syste	em	Impact Resistant	Requirement
1		No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
	Type of Installation	Lastallia accordance with describe No. 00, 02475
	Wall Framing	Install in accordance with drawing No. 08-03475,
1	Fasteners	dated July 16, 2019. Revision A dated February 8,
	Fastener Location/Spacing	2022. Signed and sealed by Luis R. Lomas, PE. on February 17, 2022.
	Fastener Penetration	rebluary 17, 2022.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.