

Product Evaluation

WIN1802 | 0622

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1802

Effective Date: June 1, 2022

Re-evaluation Date: January 2026

Product Name: Series 142.000/143.000/145.000 Vinyl Picture Windows, Fin and Frame Installation, Impact Resistant

Manufacturer: Showcase Windows and Doors
12613 Citypark Dr. Unit 100
Missouri City, TX 77489
(713) 926-8500

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 142.000/143.000/145.000 Vinyl Picture Windows	FW-C80 (64 x 84) Missile Level D	+50 / -50 psf
2	Series 142.000/143.000/145.000 Vinyl Picture Windows	FW-C80 (50 x 63) Missile Level D (48 x 60)	+60 / -60 psf

Product Dimensions:

System	Overall Size	Fixed Sash Daylight Opening Size
1	64" x 84"	59" x 79"
2	48" x 60"	43" x 55"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 839-1040 / 839-214
	Product Name	142.000/143.000/145.000NC/Rep Imp Fixed
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-05/E1996-06 Missile Level D
2	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 839-1041 / 839-226
	Product Name	142.000/143.000/145.000 NC/Rep Imp Fixed
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-05/E1996-09 Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1-2	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System		
1	Type of Installation	Install in accordance with drawing No. 08-03106, dated April 26, 2017. Revision A dated December 14, 2021. Signed and sealed by Luis R. Lomas, P.E. on February 2, 2022.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
2	Type of Installation	Frame Installation
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 PPH screws
	Fastener Location/Spacing	Head/Sill: 6", 20", 30", and 44" measuring from the left side jamb. Side jambs: 6", 20", 32", 44", and 57" measuring from the head jamb
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.