

Product Evaluation

WIN1952 | 0822

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1952

Effective Date: August 1, 2022

Re-evaluation Date: June 2025

Product Name: Model 3001/3B01/3A01/3AB1 ST Vinyl Double Hung Windows, Frame Installation, Non-Impact Resistant

Manufacturer: Associated Materials, Inc.
3773 State Road
Cuyahoga Falls, OH 44223
(330) 922-5350

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Model 3001/3B01/3A01/3AB1 ST Vinyl Double Hung Windows; X/X	R-PG25 (44 x 96)-H	+25 / -25 psf
2	Model 3001/3B01/3A01/3AB1 ST Vinyl Double Hung Windows; X/X	LC-PG25 (44 x 75)-H	+25 / -25 psf
3	Model 3001 ST Vinyl Double Hung Windows; X/X	LC-PG45 (36 x 72)-H	+50 / -55 psf
4	Model 3001/3B01/3A01/3AB1 ST Vinyl Double Hung Windows; X/X	R-PG40 (36 x 78)-H	+40 / -40 psf
5	Model 3001 ST Vinyl Double Hung Windows; X/X	LC-PG50 (36 x 60)-H	+55 / -60 psf

General Description:

System	Description	Label Rating	Design Pressure Rating
6	Model 3001/3B01/3A01/3AB1 ST Vinyl Double Hung Windows; X/X	LC-PG30 (44 x 75)-H	+30 / -30 psf
7	Model 3001/3B01/3A01/3AB1 ST Vinyl Double Hung Windows; X/X	R-PG25 (48 x 84)-H	+25 / -25 psf
8	Model 3001/3B01/3A01/3AB1 ST Vinyl Double Hung Windows; X/X	R-PG35 (48 x 72)-H	+35 / -35 psf
9	Model 3001/3B01/3A01/3AB1 ST Vinyl Double Hung Windows; X/X	LC-PG40 (44 x 72)-H	+40 / -40 psf
10	Model 3001/3B01/3A01/3AB1 ST Vinyl Double Hung Windows; X/X	R-PG35 (52 x 62)-H	+35 / -35 psf

Product Dimensions:

System	Overall Size	Upper Sash Size	Lower Sash Size
1	44" x 96"	39-7/8" x 46-3/8"	40-7/8" x 47-1/2"
2, 6	44" x 75"	39-7/8" x 35-7/8"	40-7/8" x 37"
3	36" x 72"	31-7/8" x 34-3/8"	32-7/8" x 35-1/2"
4	36" x 78"	31-7/8" x 37-3/8"	32-7/8" x 38-1/2"
5	36" x 60"	31-7/8" x 28-3/8"	32-7/8" x 29-1/2"
7	48" x 84"	43-7/8" x 40-3/8"	44-7/8" x 41-1/2"
8	48" x 72"	43-7/8" x 34-3/8"	44-7/8" x 35-3/8"
9	44" x 72"	37-7/8" x 34-3/8"	38-7/8" x 35-3/8"
10	52" x 62"	47-7/8" x 29-3/8"	48-7/8" x 30-1/2"

Product Identification (Certification Label on Window):

System		
1-2, 4 6-10	Certification Agency	AAMA
	Manufacturer's Name or Code Name	AMI-05
	Product Name	3001 ST/3B01 ST/3A01 ST/3AB1 ST DH
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08
3, 5	Certification Agency	AAMA
	Manufacturer's Name or Code Name	AMI-05
	Product Name	3001 ST/3B01 ST/3A01 ST/3AB1 ST DH
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1-10	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Acceptance of Smaller Assemblies: Window assemblies with dimensions equal to or smaller than those specified are acceptable within the limitations in this evaluation report.

Installation:

System	
1-10	Type of Installation
	Wall Framing
	Fasteners
	Fastener Location/Spacing
	Fastener Penetration
Install in accordance with drawing No. TX-4413, dated March 27, 2014. Revision 4 dated June 22, 2022. Signed and sealed by Lyndon F. Schmidt, P.E. on June 28, 2022.	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.