

Product Evaluation

WIN1960 | 0523

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1960

Effective Date: May 1, 2023

Re-evaluation Date: January 2026

Product Name: Model 143.191 CA Vinyl Casement Windows, Fin or Frame Installation, Non-Impact Resistant

Manufacturer: Showcase Window and Door Company LLC
12613 Citypark Dr. Unit 100
Missouri City, TX 77489
(713) 926-8500

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Model 143.191 CA Vinyl Casement Windows; X	LC-PG70 (37 x 76)-C	+70 / -70 psf

Product Dimensions:

System	Overall Size	Operable Sash Size
1	37" x 76"	35-3/8" x 73-1/8"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 839-1098
	Product Name	143.191 CA Rep/NC Casement
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

Compliance: The products comply with AAMA/WDMA/CSA 101/I.S.2/A440-17 as referenced in the 2018 IRC and 2018 IBC.

Impact Resistance:

System	Impact Resistant	Requirement
1	No	These products have not been tested for windborne debris resistance. An impact protection system is required when installing this product in areas where windborne debris protection is required.

Installation:

The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing with twenty-eight (28) No. 8 PPH screws. Along each side jamb, locate the screws approximately 6" from each corner and 7" on center. Along the head and sill, locate the screws approximately 6" from each corner and 8" on center. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.