

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

WIN2017 | 0221

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2017

Effective Date:February 1, 2021Re-evaluation Date:March 2023

Product Name: Series E4000COS Aluminum Out-Swing Casement Windows, Frame Installation, Non-Impact resistant

Manufacturer: All Seasons Commercial Division 1293 N Harvey Mitchell Pkwy. Bryan, TX 77803 (800) 444-1444

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series E4000COS Aluminum Out- Swing Casement Windows; X	AW-PG95 (36 x 60)-C	+95 / -95 psf

Product Dimensions:

System	Overall	Operable	Fixed Sash
	Size	Sash Size	Daylight Opening Size
1	36" x 60"	34-5/16" x 58-1/4"	29-1/4" x 53-5/16"

Product Identification (Certification Label on Window):

System		
	Certification Agency	NAMI
1	Manufacturer's Name or Code Name	All Seasons Commercial Division
1	Product Name	E4000COS Aluminum O/S Casement
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

	System		
Wall Framing Southern Yellow Pine dim		Type of Installation	Screw Through Frame
		Wall Framing	Southern Yellow Pine dimension lumber
		No. 10 x 2-1/2" flat head screws	
	1	Fastener Location/Spacing	Head/Sill: 6" from each corner and at the midspan
			Side Jambs: 7" and 19" from each corner and at
			the midspan
		Fastener Penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.