

Product Evaluation

WIN2174 | 0719

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2174

Effective Date: July 1, 2019

Re-evaluation Date: July 2023

Product Name: Architect Contemporary/ Lifestyle without HGP Series Aluminum Clad Wood Vent Casement Windows, Non-Impact Resistant

Manufacturer: Pella Corporation
102 Main Street
Pella, IA 50219
(641) 621-1000

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Architect Contemporary/ Lifestyle w/o HGP Series Aluminum Clad Wood Vent Casement Windows	LC-PG50 25 x 73-C	+50 / -50 psf
2	Architect Contemporary/ Lifestyle w/o HGP Series Aluminum Clad Wood Vent Casement Windows	LC-PG50 35 x 59-C	+50 / -50 psf
3	Architect Contemporary/ Lifestyle w/o HGP Series Aluminum Clad Wood Vent Casement Windows	LC-PG30 35 x 73-C	+30 / -30 psf

Product Dimensions:

System	Overall Size	Sash Size
1	25" x 73"	23" x 71"
2	35" x 59"	33" x 57"
3	35" x 73"	33" x 71"

Product Identification (Certification Label on Window):

System		
1-3	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Pella Corporation
	Product Name	Architect Series- Casement OR Lifestyle Series- Casement
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-11

Impact Resistance:

System	Impact Resistant	Requirement
1-3	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1-3	Type of Installation	Install in accordance with Pella Corporation drawing No. 1920T, dated June 8, 2015, revised January 23, 2019. Signed and sealed by Warren W. Schaefer, P.E. on January 23, 2019.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.