TDI Texas Department of Insurance

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

Product Evaluation

WIN2244 | 0222

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2244

Effective Date:February 1, 2022Re-evaluation Date:February 2026

Product Name: H3 2.0 Aluminum Clad Vinyl Wood Main Frame, Aluminum Clad Wood Sash, Casement Windows, Fin Installation, Non-Impact Resistant

Manufacturer: Sierra Pacific Windows 575 South Whelen Ave. Medford, WI 54451 (715) 748-2011

General Description:

System	Description	Label Rating	Design Pressure Rating
1	H3 2.0 Casement Window; X	R-PG50 (36 x 84)-C	+50 / -60 psf
2	H3 2.0 Casement Window; X	CW-PG50 (36 x 84)-C	+50 / -60 psf
3 H3 2.0 Insert Casement Window; X		R-PG45 (35.5 x 83.5)-C	+45 / -45 psf

Product Dimensions:

System	Overall Size	Operable Sash Size
1-2	35-1/2" x 83-1/2"	34" x 81-3/4"
3	35-1/2" x 83-1/2"	33-3/4" x 81-3/4"

Product Identification (Certification Label on Window):

System		
	Certification Agency	WDMA
1-2	Manufacturer's Name	Sierra Pacific Windows
1-2	Product Name	H3 2.0 Casement
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11
	Certification Agency	WDMA
3	Manufacturer's Name	Sierra Pacific Windows
5	Product Name	H3 2.0 Insert Casement
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08,11,17

Impact Resistance:

System	Impact Resistant	Requirement
1-3	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
	Type of Installation	Nail Fin Installation
	Wall Framing	Spruce-Pine-Fir dimension lumber
1-2	Fasteners	No. 8 PPH screws
1-2	Fastener Location/Spacing	1-2" from each corner and 6-8" on center
		along the perimeter
	Fastener Penetration	Minimum of 1-1/2" into the wall framing
	Type of Installation	Frame Installation
	Wall Framing	Spruce-Pine-Fir dimension lumber
3	Fasteners	No. 8 x 3" PFH screws
5	Fastener Location/Spacing	9" from each corner, 21" on center, and one at the
		center along the side jambs
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.