

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

Product Evaluation

WIN2265 | 1023

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2265 **Effective Date:** October 1, 2023

Re-evaluation Date: June 2025

Product Name: Series 1620 Vinyl Single Hung Windows, Fin and Frame Installation, Impact

Resistant

Manufacturer: MI Windows and Doors

650 West Market Street

Gratz, PA 17030 (717) 365-3300

General Description:

| System | Description | Label Rating | Design Pressure Rating | |
|--------|--|-------------------|---------------------------|--|
| 1 | Series 1620 Vinyl Single Hung Windows, | LC-PG50 (52 x 75) | +50 / -50 psf | |
| ' | Fin, Finless/Flange Installed; O/X | Missile Level D | +50 / -50 psi | |
| 2 | Series 1620 Vinyl Single Hung Windows, | LC-PG50 (38 x 75) | +60 / -70 psf | |
| | Fin and Finless Installed; O/X | Missile Level D | +60 / -70 psi | |
| 3 | Series 1620 Vinyl Single Hung Windows, | LC-PG50 (48 x 84) | 150 / 50 pcf | |
| | Fin, Finless/Flange Installed; O/X | Missile Level D | +50 / -50 psf | |

Product Dimensions:

| System | Overall Size | Operable Sash Size | Fixed Sash Daylight Opening Size |
|--------|---------------|--------------------|-------------------------------------|
| 1 | 52-1/8" x 75" | 49-1/2" x 37-1/4" | 47-1/2" x 34" |
| 2 | 38" x 75" | 35-3/8" x 37-1/4" | 33-3/8" x 33-3/4" |
| 3 | 48" x 84" | 45-5/16" x 41-3/4" | 43-3/8" x 38-5/16" |

Product Identification (Certification Label on Window):

| System | | | |
|--------|----------------------|--|--|
| | Certification Agency | AAMA | |
| | Code Name | MTL-12 | |
| | Product Name | 1620 | |
| 1-3 | | AAMA/WDMA/CSA 101/I.S.2/A440-08 (System 1) | |
| | Test Standards | AAMA/WDMA/CSA 101/I.S.2/A440-11 (System 2 | |
| | Test Standards | AAMA/WDMA/CSA 101/I.S.2/A440-17 (System 3) | |
| | | ASTM E1886-/E1996; Missile Level D | |

Impact Resistance:

| System | Impact Resistant | Requirement |
|--------|------------------|---|
| 1-3 | Yes | These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies. |

Installation:

| System | | | |
|--------|---------------------------|---|--|
| | Type of Installation | Nail Fin Installation | |
| | Wall Framing | Spruce-Pine-Fir dimension lumber | |
| 1-3 | Fasteners | No. 6 x 1-5/8" flat head screws | |
| | Fastener Location/Spacing | 3" from each corner and 8" on center | |
| | Fastener Penetration | Minimum of 1-1/2" into the wall framing | |
| | Type of Installation | Screw Through Frame Installation | |
| | Wall Framing | Spruce-Pine-Fir dimension lumber | |
| | Fasteners | Fasteners No. 8 x 2" flat head screws | |
| 1 | | J-hooks: two No. 8 x 2" pan head screws | |
| ' | Fastener Location/Spacing | Head/Sill: 4" from each corner | |
| | | Side Jambs: 13-1/4" on center | |
| | | J-hooks: one per side jamb | |
| | Fastener Penetration | Minimum of 1-1/2" into the wall framing | |

Installation:

| System | | | |
|--------|---------------------------|---|--|
| | Type of Installation | Screw Through Frame Installation | |
| | Wall Framing | Spruce-Pine-Fir dimension lumber | |
| | Fasteners | No. 8 x 1-1/2" pan head screws | |
| 2 | | J-hooks: two No. 8 x 2" pan head screws | |
| ۷ | Fastener Location/Spacing | 3" from each corner and 11" on center along the | |
| | | side jambs. | |
| | | J-hooks: one per side jamb | |
| | Fastener Penetration | Minimum of 1-1/2" into the wall framing | |
| | Type of Installation | Screw Through Frame Installation | |
| | Wall Framing | Spruce-Pine-Fir dimension lumber | |
| | Fasteners | No. 8 x 2-1/2" flat head screws | |
| 3 | | J-hooks: two No. 8 x 2" pan head screws | |
| | Fastener Location/Spacing | 3" from each corner and 12" on center along the | |
| | | head and side jambs | |
| | | J-hooks: one per side jamb | |
| | Fastener Penetration | Minimum of 1-1/2" into the wall framing | |

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.