TDI Texas Department of Insurance

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

Product Evaluation

WIN2272 | 0621

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2272

Effective Date:June 1, 2021Re-evaluation Date:February 2024

Product Name: WinForce Vinyl Casement Window, Non-Impact Resistant

Manufacturer: Northeast Building Products 4280 Aramingo Ave Philadelphia, PA 19124 (215) 535-7110

General Description:

System	Description	Label Rating	Design Pressure Rating
1	WinForce Vinyl Casement Window (Fin & Flange/Equal Leg)	CW-PG60 37 x 75-Type C	±60 psf

Product Dimensions:

System	Overall Size	Operable Sash Size
1	37" x 75"	34" x 72-1/2"

Product Identification (Certification Label on Window):

	System		
		Certification Agency	Keystone
	1	Manufacturer's Name or Code Name	CAR Number: 86-153
	I	Product Name	WinForce Casement
		Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
	Type of Installation	Install the windows in accordance with Drawing
	Wall Framing	TDI-WinForce-CA-NI; sheets 1 through 4 of 4;
1	Fasteners	dated April 13, 2017; Revision A. Drawings are
	Fastener Location/Spacing	signed, sealed, and dated February 18, 2021, by
	Fastener Penetration	Lucas A. Turner, P.E.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.