

## Product Evaluation

WIN2461 | 0320

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-2461

**Effective Date:** March 1, 2020

**Re-evaluation Date:** March 2024

**Product Name:** Model 1310 Premium Coastal Aluminum Clad Wood Direct Set Fixed Windows, Impact Resistant

**Manufacturer:** Weather Shield Mfg., Inc.  
One Weather Shield Plaza  
Medford, WI 54451  
(715) 748-2100

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Model 1310 Premium Coastal Direct Set Fixed Windows	CW-PG55 (72 x 84)-FW Missile Level D	+55 / -70 psf
2	Model 1310 Premium Coastal Direct Set Fixed Windows; Twin	LC-PG55 Span (83.5) x TW (71.50)-MA Missile Level D	+55 / -70 psf

### Product Dimensions:

System	Overall Size	Fixed Daylight Opening Size
1	71.50" x 83.50"	67-11/16" x 79-11/16"
2	143" x 83.50"	67-11/16" x 79-11/16" (2)

**Product Identification (Certification Label on Window):**

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Weather Shield
	Product Name	Model 1310 Premium Coastal Direct-set Clad Wood
	Test Standards	AAMA/WDA/CSA 101/I.S.2/A440-11 ASTM E1886-05/E1996-12 Missile Level D
2	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Weather Shield
	Product Name	Model 1310 Premium Coastal Direct-set Twin Clad Wood
	Test Standards	AAMA/WDA/CSA 101/I.S.2/A440-11 ASTM E1886-05/E1996-12; Missile Level D AAMA 450-10

**Impact Resistance:**

System	Impact Resistant	Requirement
1-2	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

**Installation:****Nail Fin Installation (System1):**

The wood wall framing members must be minimum Southern Yellow Pine dimension lumber. The window assembly is secured to the wall framing using an integral aluminum nailing fin. The nailing fin is secured to the wall framing using minimum No. 6 x 1-5/8" screws spaced approximately 3" from each corner and 8"-10" on center along the perimeter of the window. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

**Clip Installation (System 1):**

The wood wall framing members must be minimum Southern Yellow Pine dimension lumber. The window assembly is secured to the wall framing using 1-1/2" x 5-1/2" long, 20-gauge galvanized steel installation clips. Secure the clips to the window frame using four minimum No. 7 PFH screws and to the wall framing using four minimum No. 6 x 1-5/8" screws. Locate the clips approximately 3" from each corner and 10"-12" on center along the perimeter. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the all framing members.

**Clip Installation (System 2):**

The wood wall framing members must be minimum Southern Yellow Pine dimension lumber. The window assembly is secured to the wall framing using 1-1/2" x 5-1/2" long, 20-gauge galvanized steel installation clips. Secure the clips to the window frame using four minimum No. 7 PFH screws and to the wall framing using four minimum No. 6 x 1-5/8" screws. Locate the clips approximately 3" from each corner and 12" on center along the perimeter. Two (2) clips were located at the mull locations at the head and sill spaced approximately 1-1/2" on each side of the mull center. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the all framing members.

**Nail Fin Installation (System2):**

The wood wall framing members must be minimum Southern Yellow Pine dimension lumber. The window assembly is secured to the wall framing using an integral aluminum nailing fin. The nailing fin is secured to the wall framing using minimum No. 6 x 1-5/8" screws spaced approximately 3" from each corner and 8"-10" on center along the perimeter of the window. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members. Two clips were located at the mull locations at the head and sill spaced approximately 1-1/2" on each side of the mull center.

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.