

## Product Evaluation

WIN2540 | 0121

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-2540

**Effective Date:** January 1, 2021

**Re-evaluation Date:** September 2023

**Product Name:** Vanguard Series Vinyl Fixed Casement Windows, Frame Installation, Non-Impact Resistant

**Manufacturer:** Sunrise Windows, LTD.  
200 Enterprise Drive  
Temperance, MI 48182  
734-847-8778

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Vanguard Series Vinyl Fixed Casement Windows; O	LC-PG50 (59 x 63)-FW	+50 / -60 psf
2	Vanguard Series Vinyl Fixed Casement Windows; O	LC-PG65 (72 x 90)-FW	+65 / -75 psf
3	Vanguard Series Vinyl Fixed Casement Windows; O	LC-PG70 (107 x 65)-FW	+70 / -75 psf

**Product Dimensions:**

System	Overall Size	Fixed Sash Daylight Opening Size
1	59-1/16" x 63"	53-9/16" x 57-1/2"
2	72" x 90"	66-1/2" x 84-1/2"
3	107" x 65"	101-1/2" x 59-1/2"

**Product Identification (Certification Label on Window):**

System		
1-3	Certification Agency	NAMI
	Manufacturer's Name or Code Name	Sunrise Windows & Doors
	Product Name	Vinyl Fixed Casement Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

**Impact Resistance:**

System	Impact Resistant	Requirement
1-3	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System		
1-3	Type of Installation	Install in accordance with drawing No. TX-5045, dated May 5, 2020. Signed and sealed by Lyndon F. Schmidt, P.E. on July 16, 2020.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.