

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

# **Product Evaluation**

WIN2560 | 0221

**Engineering Services Program** 

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-2560 **Effective Date:** February 1, 2021

**Re-evaluation Date:** January 2024

Product Name: Inspira Vinyl Casement Picture Windows, Fin and Frame Installation, Non-Impact

Resistant

Manufacturer: Northeast Building Products

4280 Aramingo

Philadelphia, PA 19124

(215) 535-7110

#### **General Description:**

System	Description	Label Rating	Design Pressure Rating	
1	Inspira New Construction Vinyl	Class LC-PG30 72 x 72	±30 psf	
'	Casement Picture Windows	Type FW	±30 μ31	
2	Inspira Replacement Vinyl	Class LC-PG60 72 x 72	4.60 pcf	
	Casement Picture Windows	Type FW	±60 psf	
3	Inspira New Construction Vinyl	Class LC-PG40 60 x 60	140 mgf	
	Casement Picture Windows	Type FW	±40 psf	

**General Description (Continued):** 

System	Description	Label Rating	Design Pressure Rating
4	Inspira Replacement Vinyl Casement Picture Windows	Class LC-PG55 60 x 60 Type FW	±55 psf

**Note 1:** Additional size of 42" x 72" Replacement provided in installation drawing TDI-INSPIRA-CAPW-NI in order to allow wider anchor spacings at that size; this size is qualified by and uses same Certifications and Labels as System 2.

**Note 2:** Additional size of 46" x 60" Replacement provided in installation drawing TDI-INSPIRA-CAPW-NI in order to allow wider anchor spacings at that size; this size is qualified by and uses same Certifications and Labels as System 4.

### **Product Dimensions:**

System	Overall Size	Daylight Opening Size
1, 2	72" x 72"	65-5/8" x 65-5/8"
3, 4	60" x 60"	53-1/2" x 53-1/2"

### **Product Identification (Certification Label on Window):**

System		
	Certification Agency	Keystone
	Manufacturer's Name or Code Name	86-718
1	Product Name	Inspira Casement
		Picture Window (NC)
	Test Standards	AAMA/WDMA/CSA 101/IS2/A440-11
	Certification Agency	Keystone
	Manufacturer's Name or Code Name	86-719
2	Product Name	Inspira Casement
		Picture Window (Repl)
	Test Standards	AAMA/WDMA/CSA 101/IS2/A440-11
	Certification Agency	Keystone
	Manufacturer's Name or Code Name	86-720
3	Product Name	Inspira Casement
		Picture Window (NC)
	Test Standards	AAMA/WDMA/CSA 101/IS2/A440-11
	Certification Agency	Keystone
4	Manufacturer's Name or Code Name	86-721
	Product Name	Inspira Casement
		Picture Window (Repl)
	Test Standards	AAMA/WDMA/CSA 101/IS2/A440-11

# **Impact Resistance:**

System	Impact Resistant	Requirement
1-4	No	Provide an impact protective system when installing the product in areas that require windborne debris.

# **Installation:**

System		
	Type of Installation	Install the windows in accordance with Drawing
	Wall Framing	TDI-INSPIRA-CAPW-NI; sheets 1 through 3 of 3;
1-4	Fasteners	dated February 20, 2020; Revision 0; Signed,
	Fastener Location/Spacing	sealed, and dated March 18, 2020 by Lucas A.
	Fastener Penetration	Turner, P.E.

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.