

## Product Evaluation

WIN2702 | 0322

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-2702

**Effective Date:** March 1, 2022

**Re-evaluation Date:** March 2026

**Product Name:** Pella Impervia Series Model 2.0 Fiberglass Fixed Windows, Non-Impact Resistant

**Manufacturer:** Pella Corporation  
102 Main Street  
Pella, IA 50219  
(641) 621-1000

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Impervia Model 2.0 Direct Set Fixed Window, Integral Mull; OO	CW-PG50 (32.5 x 74.5)-FW	+50 / -55 psf
2	Impervia Model 2.0 Direct Set Fixed Window, Integral Mull; OO	CW-PG50 (52 x 65)-FW	+50 / -55 psf
3	Impervia Model 2.0 Direct Set Fixed Window, Integral Mull; OO	CW-PG50 (86.25 x 83.5)-FW	+50 / -55 psf
4	Impervia Model 2.0 Direct Set Fixed Window, Integral Mull; OO	CW-PG50 (118 x 59)-FW	+50 / -55 psf
5	Impervia Model 2.0 Direct Set Fixed Window; O	CW-PG50 (120.75 x 83.5)-FW	+50 / -55 psf

**General Description:**

System	Description	Label Rating	Design Pressure Rating
6	Impervia Model 2.0 Direct Set Fixed Window; O	CW-PG50 (132 x 76.375)-FW	+50 / -55 psf
7	Impervia Model 2.0 Direct Set Fixed Window; O	CW-PG50 (143.5 x 50.5)-FW	+50 / -55 psf
8	Impervia Model 2.0 Direct Set Fixed Window, Integral Mull; OO	CW-PG50 (143.5 x 59)-FW	+50 / -55 psf
9	Impervia Model 2.0 Direct Set Fixed Window; O	CW-PG50 (143.5 x 70.25)-FW	+50 / -55 psf
10	Impervia Model 2.0 Direct Set Fixed Window, Integral Mull; OO	CW-PG50 (143.5 x 83.5)-FW	+50 / -55 psf

**Product Dimensions:**

System	Overall Size	Fixed Sash Daylight Opening Size
1	32-1/2" x 74-1/2"	12-3/4" x 71"
2	52" x 65"	22-1/2" x 61-1/2"
3	86-1/4" x 83-1/2"	39-5/8" x 80"
4	118" x 59"	55-1/2" x 55-1/2"
5	120-3/4" x 83-1/2"	117-1/4" x 80"
6	132" x 76-3/8"	128-1/2" x 72-7/8"
7	143-1/2" x 50-1/2"	140" x 47"
8	143-1/2" x 59"	68-1/4" x 55-1/2"
9	143-1/2" x 70-1/4"	140" x 66-3/4"
10	143-1/2" x 83-1/2"	68-1/4" x 80"

**Product Identification (Certification Label on Window):**

System		
1-10	Certification Agency	WDMA
	Manufacturer's Name	Pella Corporation
	Product Name	Pella Impervia 2.0 Fixed Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08,11,17

**Impact Resistance:**

System	Impact Resistant	Requirement
1-10	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System	
1-10	Type of Installation
	Wall Framing
	Fasteners
	Fastener Location/Spacing
	Fastener Penetration
Install in accordance with drawing No. 1968T, dated December 18, 2019. Signed and sealed by Warren W. Schaefer, P.E. on July 17, 2020.	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.