

## Product Evaluation

WIN2705 | 0522

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-2705

**Effective Date:** May 2022

**Re-evaluation Date:** May 2026

**Product Name:** Series ET68FN Steel Narrow Frame Fixed Window, Non-Impact Resistant

**Manufacturer:** EuroLite Steel Doors & Windows  
30 N. Gould St., Suite R  
Sheridan, WY 82801  
(888) 300-9631

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series ET68FN Steel Narrow Frame Fixed Window; O	LC-PG50 (84 x 144)-FW	+50 / -50 psf

### Product Dimensions:

System	Overall Size	Fixed Sash Daylight Opening Size
1	84" x 144"	82" x 142"

**Product Identification (Certification Label on Window):**

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	EuroLite Doors & Windows
	Product Name	Series ET68FN Fixed Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11,17

**Impact Resistance:**

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System		
1	Type of Installation	Frame Installation
	Wall Framing	Southern Yellow Pine dimension lumber
	Fasteners	2-3/4" lag screws
	Fastener Location/Spacing	<b>Head/Sill:</b> 8.75" from each corner and 20" on center <b>Side Jambs:</b> 8.75" from each corner and 24" on center
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.