

Product Evaluation

WIN2716 | 0822

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2716

Effective Date: August 1, 2022

Re-evaluation Date: March 2024

Product Name: Galaxy Series Vinyl Picture Windows, Fin Installation, Non-Impact Resistant

Manufacturer: Value Windows and Doors
 13715 Murphy Road
 Suite D
 Stafford, TX 77477
 (281) 261-8900

General Description:

| System | Description | Label Rating | Design Pressure Rating |
|--------|--|----------------------|------------------------|
| 1 | Galaxy Series Vinyl Picture Windows; O | LC-PG35 (70 x 60)-FW | +35 / -35 psf |

Product Dimensions:

| System | Overall Size | Daylight Opening Size |
|--------|--------------|-----------------------|
| 1 | 70" x 60" | 64-1/4" x 54-1/2" |

Product Identification (Certification Label on Window):

| System | | |
|--------|----------------------------------|---------------------------------|
| 1 | Certification Agency | AAMA |
| | Manufacturer's Name or Code Name | VAL-3 |
| | Product Name | Galaxy PW |
| | Test Standards | AAMA/WDMA/CSA 101/I.S.2/A440-11 |

Impact Resistance:

| System | Impact Resistant | Requirement |
|--------|------------------|--|
| 1 | No | Provide an impact protective system when installing the product in areas that require windborne debris protection. |

Installation:

| System | | |
|--------|---------------------------|--|
| 1 | Type of Installation | Nail Fin Installation |
| | Wall Framing | Southern Yellow Pine dimension lumber |
| | Fasteners | Minimum No. 8 PFH screws |
| | Fastener Location/Spacing | Approximately 3" from each corner and approximately 10" on center along the perimeter. |
| | Fastener Penetration | Minimum of 1-1/2" into the wall framing |

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.