

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

# **Product Evaluation**

#### WIN2750 | 0523

**Engineering Services Program** 

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-2750 **Effective Date:** May 1, 2023

**Re-evaluation Date:** April 2027

Product Name: F150 Vinyl Fixed Picture Windows, Fin and Frame Installation, Non-Impact

Resistant

Manufacturer: NT Window

2900 W. Seminary Drive Fort Worth, TX 76133 (800) 969-8830

**General Description:** 

System	Description	Label Rating	Design Pressure Rating
1	F150 Vinyl Fixed Picture Windows; Frame; O	R-PG60 (52 x 84)-FW	+60 / -60 psf
2	F150 Vinyl Fixed Picture Windows, Fin; O	R-PG60 (52 x 84)-FW	+60 / -60 psf
3	F150 Vinyl Fixed Picture Windows; Frame; O	LC-PG50 (72 x 72)-FW	+50 / -50 psf
4	F150 Vinyl Fixed Picture Windows, Fin; O	LC-PG50 (72 x 72)-FW	+50 / -50 psf

## **Product Dimensions:**

System	Overall Size	Daylight Opening Size
1, 2	52" x 84"	48-3/4" x 80-3/4"
3, 4	72" x 72"	68-3/4" x 68-3/4"

## **Product Identification (Certification Label on Window):**

System		
1-4	Certification Agency	AAMA
	Manufacturer's Name or Code Name	NT
	Product Name	F150 PW
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-17

## **Impact Resistance:**

System	Impact Resistant	Requirement
1-4	INΟ	Provide an impact protective system when installing the
		product in areas that require windborne debris protection.

#### Installation:

System		
1, 3 (FRAME)	Type of Installation	Frame Installation
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 x 2-1/2" washer head wood screws
	Fastener Location/Spacing	3" from each end and 12" o.c. max.
	Fastener Penetration	Minimum of 1-1/2" into the wall framing
2, 4 (FIN)	Type of Installation	Fin Installation
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 x 2-1/2" washer head wood screws
	Fastener Location/Spacing	3" from each end and 12" o.c. max.
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.