

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

Product Evaluation

WIN2763 | 0823

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2763 **Effective Date:** August 1, 2023

Re-evaluation Date: August 2027

Product Name: Elevate Fiberglass Clad Wood Casement Picture Windows, Fin and Frame

Installation, Impact Resistant

Manufacturer: Marvin

Highway 11 West Warroad, MN 56763 (218) 386-4021

General Description:

| System | Description | Label Rating | Design Pressure Rating | |
|--------|-------------------------------------|---|---------------------------|--|
| 1 | Elevate Casement Picture Windows | LC-PG55 (56 x 71.13) Missile Level D | +55 / -65 psf | |
| | Elevate Casement Picture | LC-PG55 (72 x 55.13) | | |
| 2 | Windows | Missile Level D | +55 / -65 psf | |
| 3 | Elevate Casement Picture | LC-PG55 (32 x 63.13) | LEE / GE pof | |
| | Windows | Missile Level D | +55 / -65 psf | |

Product Dimensions:

| System | Overall Size | Sash Size |
|--------|---------------|---------------------|
| 1 | 56" x 71-1/8" | 54-5/16" x 69-7/16" |
| 2 | 72" x 55-1/8" | 70-5/16" x 53-7/16" |
| 3 | 32" x 63-1/8" | 30-5/16" x 61-7/16" |

Product Identification (Certification Label on Window):

| System | | | |
|--------|----------------------|------------------------------------|--|
| 1-3 | Certification Agency | WDMA | |
| | Manufacturer's Name | Marvin | |
| | Product Name | Elevate Casement Picture IZ3 | |
| | | AAMA/WDMA/CSA 101/I.S.2/A440-11,17 | |
| | Test Standards | ASTM E1886-13a/E1996-14a | |
| | | Missile Level D | |

Impact Resistance:

| System | Impact Resistant | Requirement |
|--------|------------------|---|
| 1-3 | Yes | These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies. |

Installation (One of the following):

Screws Through Frame: The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing with minimum No. 8-18 x 3" screws. Locate the fasteners approximately 4" from each corner and at midspan on the head jamb. Locate the fasteners 3-1/2", 35-1/2", and 67-1/2" up from the sill on side jambs. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Nailing Fin with Clips: The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing using the nailing fin with minimum 2" long, 12-gauge smooth shank roofing nails. Locate the fasteners approximately 4" from each corner and 7" o.c. along the perimeter of the window. In addition, installation clips shall be secured to the window along head jamb and side jambs with three (3) No. 7 x 5/8" wood screws. Attach installation clips to wall framing with three (3) No. 8 x 1-1/4" drywall screws. Locate clips 6" from each corner and spaced 18" on center.

Structural Brackets: The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing with structural brackets (minimum 19-gauge x 1-3/4" x 1-2/3" galvanized steel). Secure the brackets to the window frame with two (2) No. 7 x 5/8" screws and to the wall framing with 2 (2) No. 8 x 1-5/8" screws. Locate the brackets approximately 6" from each end and 12" (max.) on center along all sides. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.