

Product Evaluation

WIN894 | 0422

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-894

Effective Date: April 1, 2022

Re-evaluation Date: April 2026

Product Name: Series i970/i970 HP Vinyl Fixed Picture Windows, Non-Impact Resistant

Manufacturer: Associated Materials, Inc.
3773 State Rd.
Cuyahoga Falls, OH 44223
(330) 922-5350

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series i970/i970 HP Vinyl Fixed Picture Windows; O	R-PG60 (52 x 78)-FW	+60 / -60 psf

Product Dimensions:

System	Overall Size	Fixed Sash Daylight Opening Size
1	52" x 78"	46-1/2" x 72-1/2"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	AMI-05
	Product Name	I970/i970 HP PW
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1	Type of Installation	Install in accordance with drawing No. TX-4411, dated November 25, 2013. Revision 1 dated June 16, 2020. Signed and sealed by Lyndon F. Schmidt, P.E. on June 16, 2020.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.