

## Product Evaluation

WIN924 | 0423

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-924

**Effective Date:** April 1, 2023

**Re-evaluation Date:** April 2027

**Product Name:** Ultimate Prime Wood Double Hung Magnum Windows, Frame Installation, Non-Impact Resistant

**Manufacturer:** Marvin  
 P.O. Box 100  
 Highway 11 West  
 Warroad, MN 56763  
 (800) 346-5044

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Ultimate Prime Wood Double Hung Magnum Windows; X/X	LC-PG50 (53.38 x 105)	+50 / -50 psf
2	Ultimate Prime Wood Double Hung Magnum Windows; X/X	LC-PG35 (59.38 x 121)	+35 / -35 psf

### Product Dimensions:

System	Overall Size	Top Sash Size	Bottom Sash Size
1	53-3/8" x 105"	50-7/16" x 50-13/16"	50-7/16" x 52-5/8"
2	59-3/8" x 121"	56-7/16" x 58-13/16"	56-7/16" x 60-5/8"

**Product Identification (Certification Label on Window):**

System		
1-2	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Marvin
	Product Name	UL WD DBLHNG M
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11,17

**Impact Resistance:**

System	Impact Resistant	Requirement
1-2	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System		
1-2	Type of Installation	Screw Thru Frame
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	No. 8 x 3" screws
	Fastener Location/Spacing	5" from each corner and 12" on center along the side jambs
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.