



Product Evaluation

DR750 | 0216

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: DR-750

Effective Date: February 1, 2016

Re-evaluation Date: November 2019

Product Name: 3600 Series Vinyl Multi-Slide Doors, Non-impact Resistant

Manufacturer: Western Window Systems
5621 South 25th Street
Phoenix, AZ 85040
(602) 268-1300

General Description:

System	Description	Label Rating	Design Pressure Rating
1	3600 Series Vinyl Multi-Slide Doors; OXX	LC-PG25 180 x 96-SD	± 25 psf
2	3600 Series Vinyl Multi-Slide Doors; OXX	LC-PG40 180 x 96-SD	± 40 psf

Product Dimensions:

System	Overall Size	Operable Panel Size	Panel Daylight Opening Size
1	180" x 96"	Three: 61.26" x 93.82"	55.62" x 88.18"
2	180" x 96"	Three: 61.26" x 93.82"	55.62" x 88.18"

Product Identification (Certification Agency Label on Door):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	WWD-1
	Product Name	3600 Multi Slide Door
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08
2	Certification Agency	AAMA
	Manufacturer's Name or Code Name	WWD-1
	Product Name	3600 Multi Slide Door
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

Impact Resistance:

System	Impact Resistant	Requirement
1, 2	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:**Systems 1 and 2:**

Use minimum Southern Yellow Pine dimension lumber. The assembly is secured to the wall framing using frame of the assembly with minimum No. 8 x 2" PPH screws. The fasteners are applied in pairs. Consult the manufacturer's installation instructions for the location of the fasteners on the frame. The fasteners are required along the frame head and the frame side jambs. Space the fasteners approximately 6" from each corner and 24" on center. The fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.