

TEXAS DEPARTMENT OF INSURANCE

Engineering Services / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION

SHU-179

Effective October 1, 2010

*The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**. This product shall be subject to reevaluation **March 2013**.*

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code and the Texas Engineering Practice Act.

Series RLL-55-X Extruded Aluminum Slat Roll-Up Shutters manufactured by:

Rollac Shutter of Texas, Inc.
5331 Orange Street
Pearland, Texas 77581
(800) 880-0922

will be accepted for use in designated catastrophe areas along the Texas Gulf Coast when installed in accordance with this product evaluation and the design drawings referenced in this evaluation report.

PRODUCT DESCRIPTION

General: All of the slat roll-up shutter systems specified in this product evaluation report are permanently mounted impact protective systems. The slats are mounted with the following components: mullions, rails, and reel box assembly. Consecutive single spans and multiple spans are connected with mullions. All aluminum extrusions shall be 6063-T6 aluminum alloy unless otherwise noted on the drawings. The shutters may be trap mounted, built-out, inside mounted or any combination thereof.

Slat Types:

Extruded aluminum slat: This slat is produced from an aluminum alloy. This aluminum slat has a total width of 2.166", a maximum depth of 0.508", and a typical wall thickness of 0.048".

LIMITATIONS

Design Drawings: The roll-up shutters shall be installed in accordance with Rollac Shutters of Texas, Incorporated, Drawing No. 09-006, Sheets 1–19 of 19, dated January 15, 2009, Revision 1, dated April 27, 2010, with each sheet signed and sealed by Walter A. Tillit Jr., P.E. on May 3, 2010. The stated drawings will be referred to as approved drawings in this report. A copy of the approved drawings shall be available at the job site.

Maximum Allowable Design Load (Wood): ±30 psf to ±60 psf. This rating is for installation into wood frame structures. The wood wall framing may be minimum No. 2 Southern Yellow, Douglas Fir-Larch, or Spruce-Pine-Fir. The allowable design pressure, slat span, anchor spacing, mounting condition, and minimum separation from the glass is detailed on sheets 18 and 19 of 19 on the approved drawings. The slat span, in inches, shall be used to determine the allowable design pressure.

Maximum Allowable Design Load (Concrete and Concrete Masonry Units (CMU)): ± 30 psf to $+120/-160$ psf. The allowable design pressure slat span, anchor spacing, mounting condition, and minimum separation from the glass is detailed on sheets 10, 11, 15, 16, and 17 of 19 of the approved drawings. The slat span, in inches, shall be used to determine the allowable design pressure.

Maximum Slat Span: The maximum slat span for a given design pressure shall be determined using sheet 10 of 19 of the approved drawings, and shall not exceed 19'-8".

Maximum Mullion Span: The maximum span of the shutter system with consecutive spans and/or multiple spans is also dependent on the mullion span which is determined using the information in the applicable tables on sheets 15, 16, and 17 of 19 of the approved drawings. The mullion span is determined from the design pressure, the mullion spacing and the type of mullion.

Impact Resistance: This assembly satisfies the Texas Department of Insurance's criteria for protection from windborne debris in both the **Inland I zone** and the **Seaward zone**. The assembly passed Missile Level D specified in ASTM E 1996-05. The assembly may be installed at any height on the structure as long as the design pressure rating for the assembly is not exceeded.

INSTALLATION INSTRUCTIONS

General Installation Requirements:

All shutters shall be installed in accordance with the approved drawings. All assemblies must adhere to the limitations section of this evaluation. Wood frame structures shall be in strict accordance with Detail 1 on sheet 18 of 19.

Identification: The shutter assembly shall bear a label that identifies the manufacturer, the name of the shutter, and compliance with ASTM E 330, ASTM E 1886, and ASTM E 1996.

Anchorage: The shutters shall be anchored to the structure in accordance with the approved drawings. Anchorage of shutters to concrete, grout-filled concrete masonry units (CMU), or wood framing shall follow the mounting details on the drawings and the fasteners specified in the mounting details. For attachment to wood framing, the lag screws shall have a minimum penetration of $1 \frac{1}{2}$ inches into the wood framing members. The anchor spacing shall be as indicated on sheet 19 of 19 of the approved drawings for wood installations, and as indicated on sheet 11 of 19 for concrete or CMU installations.

Separation from Glass: The shutter shall be separated from the glass by the separation schedule in the approved drawings on sheet 10 of 19 for concrete and CMU installations, and sheet 18 of 19 for wood installations.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.