

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION

WIN-1163

Effective Date: July 1, 2013

Reevaluation Date: **June 2016**

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code and the Texas Engineering Practice Act.

Aluminum Clad Wood Hybrid Double Hung Windows, Impact Resistant, manufactured by

Lincoln Wood Products, Inc.

1400 W. Taylor Street

Merrill, Wisconsin 54452

Telephone: (715) 536-2461

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Aluminum Clad Wood Hybrid Double Hung Windows; (X/X)	H-LC50 37 x 77 Missile Level D	± 50 psf

Product Dimensions:

System	Overall Size	Bottom Sash Size	Top Sash Size
1	37.38" x 76.50"	34.50" x 37.63"	33.75" x 37.50"

Product Identification (Certification Agency Label on Window):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	LN-1
	Product Name	Aluminum Clad Hybrid DH
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05; AAMA 506-00; Missile Level D

Impact Resistance:

Impact Resistant	Requirement
Yes	These products satisfy the Texas Department of Insurance's criteria for protection from windborne debris in the Inland I and Seaward zone . The assemblies may be installed at any height on the structure as long as the design pressure rating for the assemblies is not exceeded.

Installation: The window shall be fastened to minimum Southern Yellow Pine lumber. The window is secured to the wall framing using the cellular brickmould at the head and side jambs of the window frame and with masonry clips. The brickmould shall be secured to the wall framing with minimum No. 10 x 3" long finishing nails. The fasteners shall be spaced approximately 9 inches from each corner and approximately 9 inches on center. The nailing flange is silicone sealed to the window frame. The masonry clips (1 1/2" x 6 1/2" x 0.05" galvanized steel) are required at the head and the side jambs. They are required approximately 2 inches from each end, 18 inches on center along the head, and 18 inches on center along the side jambs. Each masonry clip is secured to the window frame with two (2) No. 7 x 3/4" screws and to the wall framing with two (2) No. 6 screws. All fasteners shall be long enough to penetrate a minimum of 1 1/2 inches into the wall framing members.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC) and the International Building Code (IBC) and the Texas Revisions.