

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
 Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION

WIN-1904

Effective Date: June 1, 2014
 Reevaluation Date: **December 2015**

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

CA-2840 Vinyl Operating Casement Windows, Impact Resistant, manufactured by

PGT Industries
 1070 Technology Drive
 North Venice, Florida 34275
 Telephone: (941) 480-1600
 www.pgtindustries.com

General Description:

System	Description	Label Rating	Design Pressure Rating
1	CA-2840 Vinyl Casement	C-C80 36 x 76 Missile Level D	+80 / -115 psf
2	CA-2840 Vinyl Casement	C-C80 36 x 76 Missile Level D	+80 / -120 psf

Product Dimensions:

System	Overall Window Size	Operating Size
1	36.00" x 76.00"	33.94" x 73.94"
2	36.00" x 76.00"	33.94" x 73.94"

Product Identification (Certification Agency Label on Window):

System	Certification Agency	Keystone
1	Manufacturer's Name or Code Name	CAR 190-757; CAR 190-250
	Product Name	CA2840 Impact Casement
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E 1886-05; ASTM E 1996-05; Missile Level D
	Certification Agency	Keystone
2	Manufacturer's Name or Code Name	CAR 190-756; CAR 190-249
	Product Name	CA2840 Impact Casement
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E 1886-05; ASTM E 1996-05; Missile Level D
	Certification Agency	Keystone

Impact Resistance:

System	Impact Resistant	Requirement
1, 2	Yes	These products satisfy the Texas Department of Insurance's criteria for protection from windborne debris in the Inland I and Seaward zone . The assemblies may be installed at any height on the structure as long as the design pressure rating for the assemblies is not exceeded.

Installation:

Design Drawings: Drawing No. TDI-CA2840.1 titled "Casement Window Installation," sheets 1 through 3 of 3, dated September 13, 2013, signed and sealed by Anthony Lynn Miller, PE on September 13, 2013. The stated drawings will be referred to as the approved drawings in this evaluation report.

Wall Framing Construction: The windows may be mounted to several types of wall framing construction. The types of wall framing construction allowed, as specified on the approved drawings, include:

- Concrete (minimum compressive strength: 2,700 psi)
- Hollow concrete block; ASTM C-90
- Wood dimension lumber (minimum Southern Yellow Pine)
- Steel (18 gauge, 33 ksi)
- Steel (A36, minimum 0.125")
- Aluminum (6063-T5 , minimum 0.125")

Installation: Refer to Sheet 1 of 3 through 3 of 3 of the approved drawings for the installation details.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.