

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION
WIN-1926

Effective Date: August 1, 2014
Reevaluation Date: **June 2016**

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

Versailles Obscure Pewter Deco Composite Fixed Windows, Non-impact Resistant, manufactured by:

Glass Craft Door Company
2002 Brittmoore Road
Houston, TX 77043
Telephone: (713) 690-8282

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Versailles Obscure Pewter Deco Composite Fixed Windows	R-PG80 50 x 50 – FW FW-R80 50 x 50	± 50 psf

Product Dimensions:

System	Overall Size	Fixed Daylight Opening Size
1	49.75" x 49.75"	47.38" x 47.38"

Product Identification:

System	Certification Agency	NAMI
1	Manufacturer's Name or Code Name	Glass Craft Door Company
	Product Name	Versailles Obscure Pewter Deco Composite Fixed Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05; AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

Impact Resistant	Requirement
No	Impact protective system required when product is installed in areas where windborne debris protection is required

Installation: The window shall be secured to minimum Spruce-Pine-Fir dimension lumber. The window is secured to the wall framing using the interior of the window frame with minimum No. 8 x 2-1/2" screws. The fasteners shall be spaced approximately 4 inches from each corner and approximately 10 inches on center. The fasteners shall be long enough to penetrate a minimum of 1-1/2 inches into the wall framing members.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.