



Product Evaluation

WIN1931 | 1115

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1931

Effective Date: November 1, 2015

Re-evaluation Date: October 2017

Product Name: Model 3002 ST Vinyl Horizontal Slider Replacement Windows, Individual, Non-Impact Resistant

Manufacturer: Associated Materials, Inc.
3773 State Road
Cuyahoga Falls, OH 44223
(330) 922-5350

Distributed By: Alside Window Company
Associated Materials
Gentek Building Products
Revere Building Products

General Description:

System	Description	Label Ratings	Design Pressure
1	Model 3002 ST Horizontal Slider Window; (X/X)	LC-PG25 72 x 56 - HS	±25 psf
2	Model 3002 ST Horizontal Slider Window; (X/X)	LC-PG25 72 x 56 - HS	±25 psf
3	Model 3002 ST Horizontal Slider Window; (X/X)	R-PG60 63 x 44 - HS	±60 psf
4	Model 3002 ST Horizontal Slider Window; (X/X)	R-PG60 63 x 44 - HS	±60 psf

Product Dimensions:

System	Overall Size	Both Sash Sizes	Max. Daylight Opening
1	72" x 56"	35-1/4" x 52-1/4"	32-1/2" x 49-1/2"
2	72" x 56"	35-1/4" x 52-1/4"	32-1/4" x 49-1/4"
3	63" x 44"	30-3/4" x 40-1/4"	28" x 37-1/2"
4	63" x 44"	30-3/4" x 40-1/4"	27-3/4" x 37-1/4"

Product Identification (Certification Label on Window):

System		
1-2	Certification Agency	AAMA
	Manufacturer's Name or Code Name	Associated Materials, Inc.
	Product Name	Series 3002 ST Horizontal Slider Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08
3-4	Certification Agency	AAMA
	Manufacturer's Name or Code Name	Associated Materials, Inc.
	Product Name	Series 3002 ST Horizontal Slider Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1-4	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1-4	Type of Installation	Through Jamb
	Wall Framing	Spruce-Pine-Fir
	Fasteners	No. 8 X 2-1/2" screws
	Fastener Location/Spacing	Install the windows in accordance with Drawing No. TX-4434, title "Model 3002 ST Horizontal Slider 'Non-Impact', sheets 1 through 3 of 3, dated January 20, 2014 (revised January 13, 2015). Drawings are signed, sealed and dated January 13, 2015 by Lyndon F. Schmidt, P.E.
	Fastener Penetration	Minimum of 1-1/4" into the wall framing members

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.