

Product Evaluation

WIN1946 | 1222

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1946**Effective Date:** December 1, 2022**Re-evaluation Date:** July 2025

Product Name: Builder Series 1101 Vinyl Fixed Windows, Frame Installation, Non-Impact Resistant

Manufacturer: Ply Gem Windows & Doors
433 North Main St.
Rocky Mount, VA 24151
(800) 542-9118 ext. 413596

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Builder Series 1101 Vinyl Fixed Windows	LC-PG50 (72 x 72)-FW	+50 / -55 psf
2	Builder Series 1101 Vinyl Fixed Windows	R-PG40 (60 x 96)-FW	+40 / -60 psf
3	Builder Series 1101 Vinyl Fixed Windows	R-PG30 (72 x 84)-FW	+30 / -35 psf
4	Builder Series 1101 Vinyl Fixed Windows	R-PG50 (72 x 72)-FW	+50 / -50 psf

Product Dimensions:

System	Overall Size	Fixed Sash Daylight Opening Size
1	72" x 71-15/16"	67-3/16" x 67-3/16"
2	60" x 96"	55-5/16" x 67"
3	72" x 84"	67-5/16" x 79"
4	71-1/2" x 71-1/2"	67" x 67"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	NAMI
	Manufacturer's Name or Code Name	PWG-M-001 (BTX)
	Product Name	1101/1101FL
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-17
2	Certification Agency	NAMI
	Manufacturer's Name or Code Name	PWG-M-001 (BTX or DAL))
	Product Name	1101 / 1101N
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-17
3	Certification Agency	NAMI
	Manufacturer's Name or Code Name	PWG-M-001 (BTX)
	Product Name	1101 / 1101N
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-17
4	Certification Agency	NAMI
	Manufacturer's Name or Code Name	PWG-M-001 (BTX or PTC)
	Product Name	1101 / 1101N
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-17

Impact Resistance:

System	Impact Resistant	Requirement
1	No	These products have not been tested for windborne debris resistance. An impact protection system is required when installing this product in areas where windborne debris protection is required.

Installation:

System		
1-4	Type of Installation	Frame Installation
	Wall Framing	Southern Yellow Pine dimension lumber
	Fasteners	2-1/2" long, Minimum 11-gauge, smooth shank roofing nails
	Fastener Location/Spacing	3" from each corner and 12" on center along the perimeter
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.