



Product Evaluation

WIN2037 | 1015

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2037

Effective Date: October 1, 2015

Re-evaluation Date: March 2016

Product Name: Series 6901 NC / 6902 Rep Vinyl Horizontal Slider Windows, Fin and Frame Installation, Non-impact Resistant

Manufacturer: Window Mart
P.O. Box 570
5760 Albert Pike
Royal, AR 71968
(888) 283-6278

General Description:

| System | Description | Label Rating | Design Pressure Rating |
|--------|-----------------------------------------------------|----------------|------------------------|
| 1 | Series 6901 NC Vinyl Horizontal Slider Windows; XO | HS-C50 72 x 60 | +50 / -50 psf |
| 2 | Series 6902 Rep Vinyl Horizontal Slider Windows; XO | HS-C50 72 x 60 | +50 / -50 psf |

Product Dimensions:

| System | Overall Size | Operable Sash Size | Fixed Glass Daylight Opening Size |
|--------|-------------------|--------------------|-----------------------------------|
| 1, 2 | 71-1/2" x 59-1/2" | 34-7/8" x 56-1/4" | 32-1/4" x 54-1/2" |

Product Identification (Certification Label on Window):

| System | | |
|--------|----------------------------------|----------------------------------|
| 1 | Certification Agency | Keystone |
| | Manufacturer's Name or Code Name | CAR 588-188 |
| | Product Name | Model 6901 NC Horizontal Slider |
| | Test Standards | AAMA/WDMA/CSA 101/I.S.2/A440-05 |
| 2 | Certification Agency | Keystone |
| | Manufacturer's Name or Code Name | CAR 588-187 |
| | Product Name | Model 6902 Rep Horizontal Slider |
| | Test Standards | AAMA/WDMA/CSA 101/I.S.2/A440-05 |

Impact Resistance:

| System | Impact Resistant | Requirement |
|--------|------------------|--------------------------------------------------------------------------------------------------------------------|
| 1, 2 | No | Provide an impact protective system when installing the product in areas that require windborne debris protection. |

Installation:

| System | | |
|--------|---------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Type of Installation | Install the windows in accordance with Drawing No. 08-02342, titled "6901 NC Horizontal Slider 71-1/2 x 59-1/2," sheets 1 through 2 of 2, dated May 15, 2014, signed and sealed by Luis R. Lomas, P.E on May 16, 2014 |
| | Wall Framing | |
| | Fasteners | |
| | Fastener Location/Spacing | |
| | Fastener Penetration | |
| 2 | Type of Installation | Install the windows in accordance with Drawing No. 08-02341, titled "6902 Rep Horizontal Slider 71-1/2 x 59-1/2," sheets 1 through 4 of 4, dated May 15, 2014, signed and sealed by Luis R. Lomas, P.E on May 19, 2014 |
| | Wall Framing | |
| | Fasteners | |
| | Fastener Location/Spacing | |
| | Fastener Penetration | |

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.