



Product Evaluation

WIN2083 | 0416

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2083

Effective Date: April 1, 2016

Re-evaluation Date: December 2018

Product Name: 7122 Uniframe Composite Vinyl Twin Single Hung Window, Non-Impact Resistant

Manufacturer: Window Mart
5760 Albert Pike
P.O. Box 570
Royal, AR
(888) 283-6278

General Description:

System	Description	Label Rating	Design Pressure Rating
1	7122 Uniframe Composite Vinyl Twin Single Hung Window	R-PG35 96 x 63-H	±35 psf
2	7122 Uniframe Composite Vinyl Twin Single Hung Window	R-PG45 75 x 63-H	+45 / -50 psf

Product Dimensions:

System	Overall Size	Operating Sash Sizes	Fixed Lite Daylight Opening Size
1	96" x 63"	44-5/8" x 30-5/8"	42-1/8" x 28-1/16"
2	75" x 63"	34 1/8" x 30-5/8"	31-5/8" x 28-1/16"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 588-465
	Product Name	7122 Uniframe Twin Single Hung Composite Ass'y
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

Product Identification (Certification Label on Window) - Continued:

System		
2	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 588-467
	Product Name	7122 Uniframe Twin Single Hung Composite Ass'y
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

Impact Resistance:

System	Impact Resistant	Requirement
1, 2	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1	Type of Installation	Install the window in accordance with Drawing No. 08-02687, titled "7122 Uniframe Twin Single Hung, Composite Assembly-Non-Impact", sheets 1 through 6 of 6, dated May 4, 2015. Drawing is signed, sealed and dated May 4, 2015 by Luis R. Lomas, P.E.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
2	Type of Installation	Install the window in accordance with Drawing No. 08-0296, titled "7122 Uniframe Twin Single Hung, Composite Assembly-Non-Impact", sheets 1 through 6 of 6, dated May 4, 2015. Drawing is signed, sealed and dated May 4, 2015 by Luis R. Lomas, P.E.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.