

Product Evaluation

WIN2423 | 0821

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2423**Effective Date:** August 1, 2021**Re-evaluation Date:** August 2025

Product Name: Premium Vinyl (V-4500) Fixed Windows w/ Track Filler, Fin and Frame Installation, Impact Resistant

Manufacturer: JELD-WEN Windows and Doors
3737 Lakeport Boulevard
Klamath Falls, OR 97601
(541) 882-3451

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Premium Vinyl (V-4500) Fixed Windows w/ Track Filler; O	LC-PG50 (48 x 84)-FW Missile Level C	+50 / -55 psf
2	Premium Vinyl (V-4500) Fixed Windows w/ Track Filler; O	LC-PG50 (60 x 60)-FW Missile Level C	+50 / -55 psf
3	Premium Vinyl (V-4500) Fixed Windows w/ Track Filler; O	LC-PG50 (60 x 60)-FW Missile Level D	+50 / -55 psf
4	Premium Vinyl (V-4500) Fixed Windows w/ Track Filler; O	LC-PG50 (72 x 72)-FW Missile Level D	+50 / -55 psf
5	Premium Vinyl (V-4500) Fixed Windows w/ Track Filler; O	LC-PG50 (48 x 84)-FW Missile Level D	+50 / -55 psf

Product Dimensions:

System	Overall Size	Fixed Sash Daylight Opening Size
1	48" x 84"	44-1/2" x 80-1/2"
2	60" x 60"	56-7/16" x 56-7/16"
3	59-15/16" x 59-15/16"	56-3/8" x 56-3/8"
4	72" x 72"	68-1/2" x 68-1/2"
5	48" x 84"	44-1/2" x 80-5/8"

Product Identification (Certification Label on Window):

System		
1-2	Certification Agency	AAMA
	Manufacturer's Name or Code Name	JW-6, JW-18
	Product Name	Prem VYL (V-4500) PW w/ Track Filler
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA 506; Missile Level C
3	Certification Agency	AAMA
	Manufacturer's Name or Code Name	JW-6, JW-18
	Product Name	Prem VYL PW w/ Track Filler
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA 506; Missile Level D
4-5	Certification Agency	AAMA
	Manufacturer's Name or Code Name	JW-6, JW-18
	Product Name	Prem VYL (V-4500) PW w/ Track Filler
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA 506; Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1, 2	Yes	These products satisfy TDI's criteria for protection from windborne debris. The products may be used for basic protection in areas where the basic ultimate wind speed is less than 150 mph and greater than one mile from the coastline. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.
3, 4, 5	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System		
1	Type of Installation	Install in accordance with JELD-WEN drawing report No. SJW2016-008, titled "Premium Vinyl Fixed Pocket Filler Impact Window," dated April 28, 2021. Signed and sealed by Joseph A. Reed, P.E. on May 5, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
2	Type of Installation	Install in accordance with JELD-WEN drawing report No. NCTL-110-17-038, titled "Premium Vinyl Fixed Pocket Filler Impact Window," dated April 28, 2021. Signed and sealed by Joseph A. Reed, P.E. on May 5, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
3	Type of Installation	Install in accordance with JELD-WEN drawing report No. G6813.07-301-47, titled "Premium Vinyl Fixed Track Filler Impact Window," dated April 29, 2021. Signed and sealed by Joseph A. Reed, P.E. on May 5, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
4	Type of Installation	Install in accordance with JELD-WEN drawing report No. NCTL-110-17-030, titled "Premium Vinyl Fixed Track Filler Impact Window," dated April 29, 2021. Signed and sealed by Joseph A. Reed, P.E. on May 5, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
5	Type of Installation	Install in accordance with JELD-WEN drawing report No. NCTL-110-17-019, titled "Premium Vinyl Fixed Track Filler Impact Window," dated April 29, 2021. Signed and sealed by Joseph A. Reed, P.E. on May 5, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.